Flush Silhouette Switches

Ø22 CW Series



Sleek and stylish switches and pilot lights with a 2.5 mm-thick bezel

The CW series gives a sleek, stylish image to your machines or control panels. The surface is safer with less chance of unexpected operation or accidents by hitting the projections, and also is cleaner with less dust build-up.







• See website for details on approvals and standards.

Variety





Illuminated Pushbuttons

(round flush or extended)







Selector Switches (knob or lever) 2- and 3-position





Pilot lights (round flush or extended)





Low extension with flush silhouette.

Hard to duplicate, wave-key ensures a high level of safety.

Key Selector Switches

Wave kev 7 different key numbers



Pushbuttons (round flush or extended)

Colors

Illuminated Pushbuttons/Pilot Lights





















Bezels



Green (G)

Yellow (Y)

Amber (A)

Blue (S) Pure White (PW)

Black (plastic)

Control Boxes Emergency Stop Switches Enabling Switches Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets Circuit

Power Supplies

LED Illumination

Controllers Operator Interfaces Sensors AUTO-ID

ø16

ø22 ø30

Miniature

Pilot Lights

LB LBW ПP

Flush Bezel

Protectors

Double contact blocks

Double contact blocks with four-contact configurations.

(Illuminated pushbuttons, pushbuttons, selector switches, key selector switches)

Double contact blocks



Single contact blocks




Compact and shortest in its class


Short depth behind the panel for compact equipment.

Double: 59.9 mm*2 (maintained: 64.6 mm) Single: 39.9 mm*1 (maintained: 44.6 mm)

Switching capacity is 120V AC, 10A (resistive load). The compact style requires less depth behind the panel. Can be used with IDEC's FB and other 22 mm control boxes. No transformer needed for any voltage.



2.5 mm-thick bezel contact blocks 39.9mm*1 Panel depth



Safety

Third-generation safety construction

Two-action removal of contact blocks

IDEC's original two-action push-turn locking lever provides a higher level of safety by preventing unexpected release of the locking lever. Whether the contact block is installed securely can be checked easily from the back of the panel, with the position of the locking lever.

Locking lever integrated with guard

Prevents locking lever from unexpected release or damage by trapped wires.



IP20 Finger-safe Terminal

Finger-safe, IP20 terminal prevents electrical shock.



Control Boxes

Emergency Stop Switches

Enabling

Switches

Safety Products

Terminal Blocks

LED Illumination

Controllers

Sensors

Ø16Ø22Ø30MiniaturePilot Lights

LW-F

LBW

UP Flush Bezel

Circuit Protectors Power Supplies

Ø22 CW Series Flush Silhouette Switches

Flush bezel projects only 2.5 mm from front of panel Only 39.9 mm depth behind the panel (except single contact block, momentary).

- ø22.3 mm mounting hole compliant with IEC 60947-5-1
- 3.5-mm operator travel for pushbuttons ensures comfortable and reliable operation.
- Black plastic and metallic bezels available.
- Four-contact configuration is available with double contact blocks.
- Direct opening NC contact ensures shutdown without failure.
- Seven different keys can be chosen for key selector swiches.
- 10A contact rating. Up to three contact blocks for non-illuminated and two contact blocks for illuminated units can be connected.
- Contact blocks can be removed by the two-action locking lever integrated with a guard, ensuring safety.
- IP20 finger-safe screw terminals
- IP66/67, UL Type 4X degree of protection from panel front (see Table 1).

Applicable Standards	Mark	File No. or Organization
UL508 CSA C22.2 No.14	CULUS	UL/c-UL File No. E68961
EN60947-5-1	(€	EU Low Voltage Directive
GB14048.5	@	No. 2012010305589209 (Pilot lights: No. 2012010304567962)

Contact Ratings

Rated Insulat	300V						
Rated Thermal Current (Ith)					10A		
Rated Operat	ing Voltage (U	e)		24V	120V	240V	
		AC	Resistive Load (AC-12)	10A	10A	6A	
	Electrical Life	50/60 Hz	Inductive Load (AC-15)	10A	6A	3A	
	50,000 operations	DC	Resistive Load (DC-12)	8A	2.2A	1.1A	
Rated Operating			Inductive Load (DC-13)	4A	1.1A	0.55A	
Current (le)		000 ations	Resistive Load (AC-12)	5A	5A	3A	
	Electrical Life		Inductive Load (AC-15)	5A	3A	1.5A	
100,000 operations	100,000 operations		Resistive Load (DC-12)	4A	1.1A	0.55A	
		DC	Inductive Load (DC-13)	2A	0.55A	0.27A	
Contact Mate	erial			Silver		, and the second	

 Minimum applicable load (reference value): 3V AC/DC, 5 mA (Applicable range is subject to the operating conditions and load.)


Note: The operational current represents the classification by making and breaking currents (IEC 60947-5-1).

• UL, c-UL rating: A300, CCC rating: A300

Table 1 (Degree of Protection)

	IP65	IP66	IP67	UL Type 4X
Illuminated Pushbutton	Yes	Yes (Note)	Yes (Note)	Yes (Note)
Pilot Light	Yes	Yes	No	Yes
Pushbutton	Yes	Yes (Note)	Yes (Note)	Yes (Note)
Selector Switch	Yes	Yes	Yes	Yes
Key Selector Switch	Yes	Yes	No	Yes

Note: When used with rubber boot (CW9Z-D11, -D12)



Specifications

Specifications						
Operating Temperature		5 to +60°C (no freezing) 5 to +55°C (no freezing)				
Operating Humidity	45 to 85% RH (no co	ondensation)				
Storage Temperature	-40 to +80°C (no fre	eezing)				
Contact Resistance	50 mΩ maximum (in	50 mΩ maximum (initial value)				
Insulation Resistance	100 MΩ minimum (5	500V DC megger)				
Overvoltage Category	II (IEC 60664-1)					
Impulse Withstand Voltage	2.5 kV (IEC 60664-1	/60947-5-1)				
Pollution Degree	3 (IEC 60947-5-1)					
Vibration Resistance		5 to 55Hz, amplitude 0.5 mm z, amplitude 1.5 mm				
Shock Resistance	Operating extremes: Damage limits: 1000					
Mechanical Life (minimum operations)	Maintained: 2	on/pushbutton 2,000,000 (single contact block) 1,000,000 (double contact block) 250,000 (single contact block) 100,000 (double contact block) 250,000 (single contact block) 100,000 (double contact block) 250,000 (single contact block) 100,000 (double contact block)				
	Single contact block	50,000 (see Contact Ratings) 100,000 (see Contact Ratings)				
Electrical Life (minimum operations)	Double contact block	25,000 (see Contact Ratings) 50,000 (see Contact Ratings)				
,	Switching frequency Momentary: 1800 operations/h Maintained: 900 operations/h					
Degree of Protection (IEC 60529)		able to the left IEC 60529)				
Short-circuit Protection	250V/10A fuse (Type aM IEC 60269	9-1, IEC 602069-2)				
Electrical Shock Protection	Class II (IEC 61140)					
Terminal Style	Screw terminal (M3.5 slotted Phillips screw) (Ring terminal cannot be used.)					
Bezel Material	Polyamide					
Applicable Wire Size	Up to 2 wires of 2 mr 16AWG)	Up to 2 wires of 2 mm ² (solid wire ø1.6) maximum (14 to 16AWG)				
Recommended Tightening Torque	Terminal: 1.0 Locking ring: 1.2	to 1.3 N·m N·m				

For more information, visit http://apac.idec.com

B-007

Weight (Examples)

Illuminated Pushbutton	46g (CW1L-M1E02QH, 2 contacts) 62g (CW1L-M1E22QH, 4 contacts)		
Pilot Light	27g (CW1P-1EQH)		
Pushbutton	45g (CW1B-M1E03, 3 contacts) 52g (CW1B-M1E22, 4 contacts)		
Selector Switch	48g (CW1S-2E03, 3 contacts) 55g (CW1S-2E22, 4 contacts)		
Key Selector Switch	61g (CW1K-2AE03, 3 contacts) 68g (CW1K-2AE22, 4 contacts)		

Direct Opening of Key Selector Switch

Applicable Type	2-position (3NC)	3-position (2NC)
Minimum Operator Angle for Direct Opening Action	90°	45°
Minimum Operator Torque for Direct Opening Action	0.2 N·m	0.3 N·m
Maximum Operator Angle	90°	45°

APEM

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products **Explosion Proof**

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination Controllers

Operator

Sensors

AUTO-ID

ø16 ø22

ø30 Miniature

Pilot Lights

LB LBW

UP

Flush Bezel


LED Module

Rated Insulation Voltage (Ui)	250V	250V				
Rated Operating Voltage (Ue)	6V AC/DC	12V AC/DC	24V AC/DC	100/120V AC (50/60 Hz sine wave)	200/220V AC (50/60 Hz sine wave)	230/240V AC (50/60 Hz sine wave)
Operating Voltage Range	6V AC/DC±10%	12V AC/DC ±10%	24V AC/DC ±10%	100/120V AC ±10%	200/220V AC ±10%	230/240V AC ±10%
Illumination Color Code ②	A (amber), G (gre	en), PW (pure white)	, R (red), S (blue)			
LED Module Part No.	CW-EAQ22	CW-EAQ32	CW-EAQ42	CW-EAQH2	CW-EAQM2	CW-EAQM42
Current Draw	15 mA	15 mA	16.5 mA	18 mA	20 mA	18 mA
Life (reference value)	1 1 1 1	Approx. 30,000 hours (the illuminance is reduced to 50% of the initial intensity whe			DC at 25°C.)	
Internal Circuit	X1	/* '-132' R	Rectifying Diode Zener Diode	X1	R H	Rectifying Diode Zener Diode Resistor

- Specify an illumination color code in place of ② in the Part No.
- Use the pure white (PW) LED module for yellow illumination.


Contact Blocks

	Single Co	ntact Block	Double Contact Block			
Contact	1NO	1NC	2N0	2NC	1NO-1NC	
Part No.	YW-E10R	YW-E01	YW-EW2R0	YW-EW02	YW-EW1R1	
Shape				当場は	2) See 112 1	
Housing Color	Blue/Black	Reddish Purple	Blue/Black	Reddish Purple	Reddish Purple/Blue	
Push Rod Color	Black	Red	Black	Red	Gray	
Terminal No.	3-4	1-2	1st tier: 13-14 2nd tier: 23-24	1st tier: 11-12 2nd tier: 21-22	1st tier: (NO) 13-14 2nd tier: (NC) 21-22	
Weight (approx.)	11g		19g			



Mounting Hole Layout

IEC 60947-5-1 compliant



Note: Determine mounting centers to ensure easy operation.


Power Supplies


Miniature Pilot Lights

Part No. Development


Illuminated Pushbuttons

Note: Please use these charts to interpret the part numbers as all combinations are not possible to be created.






Pushbuttons




Selector Switches



3-position

Code	Position	Code	Positions	Code	Position	Code	Positions
3	Maintained 1 0 2	31	Spring return from right	32	Spring return from left	33	Spring return two-way

Key Selector Switches



Key Removal Position

2-position

Code	Position	Code	Positions	Code	Positions
Α	Maintained ① ②	В	Removable in left only	С	Removable in right only



002: Key retained position

Note: The key cannot be removed in a spring return position.

3-position

Code	Position	Code	Positions	Code	Positions	Code	Positions
А	Maintained ① ②	В	Removable in left and center	С	Removable in right and center	D	Removable in center only
E	Maintained (removable in right and left)	G	Removable in left only	Н	Removable in right only		

●●: Key retained position

Spring Return	Spring Return	Spring Return
from right	from left	two-way
L C R	L C R	L C R

Note: The key cannot be removed in a spring return position.

APEM

Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

ø16

ø22

ø30

Miniature

Pilot Lights

LB

LBW

UP

Control Boxes

Emergency
Stop Switches
Enabling
Switches
Safety Products

Explosion Proof
Terminal Blocks
Relays & Sockets
Circuit
Protectors
Power Supplies

LED Illumination
Controllers

Sensors AUTO-ID

Ø16Ø22Ø30MiniaturePilot Lights

LW-F LB LBW

Flush Bezel

Illuminated Pushbuttons

						Package quantity:
Shape	Operation	Operating Voltage	Contact Configuration	Black Bezel	t No. Metallic Bezel	Illumination Color Code ②
Round Flush		voitage	1NO	CW1L-M1E10Q2@	CW4L-M1E10Q2@	Oout ©
CWDL-M1			1NC	CW1L-M1E01Q22	CW4L-M1E01Q22	
CW□L-A1		6V AC/DC	1NO-1NC	CW1L-M1E11Q2@	CW4L-M1E11Q2@	
		6V AC/DC	2N0	CW1L-M1E20Q22	CW4L-M1E20Q2@	
			2NC	CW1L-M1E02Q22	CW4L-M1E02Q22	
			2NO-2NC	CW1L-M1E22Q2@	CW4L-M1E22Q2@	
			1NO 1NC	CW1L-M1E10Q3@	CW4L-M1E10Q3@	
			1NO-1NC	CW1L-M1E01Q3@ CW1L-M1E11Q3@	CW4L-M1E01Q3@ CW4L-M1E11Q3@	_
		12V AC/DC	2N0	CW1L-M1E20Q3@	CW4L-M1E20Q3©	
			2NC	CW1L-M1E02Q3©	CW4L-M1E02Q32	
			2NO-2NC	CW1L-M1E22Q3@	CW4L-M1E22Q3@	
			1NO	CW1L-M1E10Q4@	CW4L-M1E10Q4@	
			1NC	CW1L-M1E01Q42	CW4L-M1E01Q42	Specify an
		24V AC/DC	1NO-1NC	CW1L-M1E11Q4@	CW4L-M1E11Q4@	illumination color code in
		24V AG/DG	2N0	CW1L-M1E20Q42	CW4L-M1E20Q42	place of ② in the Part No.
			2NC	CW1L-M1E02Q4@	CW4L-M1E02Q4@	١
	Momentary		2NO-2NC	CW1L-M1E22Q4@	CW4L-M1E22Q4@	A: amber
			1NO	CW1L-M1E10QH2	CW4L-M1E10QH@	G: green PW: pure white
			1NC 1NO-1NC	CW1L-M1E01QH2 CW1L-M1E11QH2	CW4L-M1E01QH2 CW4L-M1E11QH2	R: red
		100/120V AC	2N0	CW1L-M1E20QH2	CW4L-M1E20QH2	S: blue
			2NC	CW1L-M1E02QH2	CW4L-M1E02QH2	Y: yellow
			2NO-2NC	CW1L-M1E22QH2	CW4L-M1E22QH2	
			1NO	CW1L-M1E10QM2	CW4L-M1E10QM2	
			1NC	CW1L-M1E01QM ²	CW4L-M1E01QM2	
		200/220V AC	1NO-1NC	CW1L-M1E11QM2	CW4L-M1E11QM2	
		200/220 v A0	2N0	CW1L-M1E20QM ²	CW4L-M1E20QM2	
(blook bozol)			2NC	CW1L-M1E02QM2	CW4L-M1E02QM2	
(black bezel)			2NO-2NC 1NO	CW1L-M1E22QM2	CW4L-M1E22QM2	
			1NC	CW1L-M1E10QM42 CW1L-M1E01QM42	CW4L-M1E10QM42 CW4L-M1E01QM42	_
			1NO-1NC	CW1L-M1E11QM4@	CW4L-M1E11QM4@	
		230/240V AC	2N0	CW1L-M1E20QM4@	CW4L-M1E20QM4@	
			2NC	CW1L-M1E02QM42	CW4L-M1E02QM4©	
			2NO-2NC	CW1L-M1E22QM4@	CW4L-M1E22QM4@	
			1NO	CW1L-A1E10Q2@	CW4L-A1E10Q22	
		6V AC/DC	1NC	CW1L-A1E01Q22	CW4L-A1E01Q2@	
			1NO-1NC	CW1L-A1E11Q22	CW4L-A1E11Q2@	
(metallic bezel)			2N0	CW1L-A1E20Q2@	CW4L-A1E20Q2@	_
, , , ,			2NC	CW1L-A1E02Q2@	CW4L-A1E02Q2@	
			2NO-2NC 1NO	CW1L-A1E22Q2@ CW1L-A1E10Q3@	CW4L-A1E22Q2@ CW4L-A1E10Q3@	_
			1NC	CW1L-A1E01Q3@	CW4L-A1E01Q3@	
			1NO-1NC	CW1L-A1E11Q3@	CW4L-A1E11Q3@	
		12V AC/DC	2N0	CW1L-A1E20Q3@	CW4L-A1E20Q3@	
			2NC	CW1L-A1E02Q3@	CW4L-A1E02Q3@	
			2NO-2NC	CW1L-A1E22Q32	CW4L-A1E22Q3@	
See B-024 for replacement LED			1NO	CW1L-A1E10Q4@	CW4L-A1E10Q42	
modules.			1NC	CW1L-A1E01Q42	CW4L-A1E01Q4@	Specify an illumination
 Marking film can be inserted to indicate legends. See B-026. 		24V AC/DC	1NO-1NC	CW1L-A1E11Q4@	CW4L-A1E11Q42	color code in place of ②
• See B-019 for dimensions.			2NO 2NC	CW1L-A1E20Q4@	CW4L-A1E20Q4@	in the Part No.
A dummy block is installed when			2NC-2NC	CW1L-A1E02Q42 CW1L-A1E22Q42	CW4L-A1E02Q4@ CW4L-A1E22Q4@	A: amber
one contact block is used.	Maintained		1NO	CW1L-A1E10QH2	CW4L-A1E10QH2	G: green
			1NC	CW1L-A1E01QH2	CW4L-A1E01QH2	PW: pure white
		100/100/110	1NO-1NC	CW1L-A1E11QH@	CW4L-A1E11QH2	R: red
		100/120V AC	2N0	CW1L-A1E20QH2	CW4L-A1E20QH2	S: blue
			2NC	CW1L-A1E02QH2	CW4L-A1E02QH2	Y: yellow
			2NO-2NC	CW1L-A1E22QH2	CW4L-A1E22QH2	_
			1NO	CW1L-A1E10QM@	CW4L-A1E10QM@	_
			1NC	CW1L-A1E01QM@	CW4L-A1E01QM@	_
		200/220V AC	1NO-1NC 2NO	CW1L-A1E11QM2 CW1L-A1E20QM2	CW4L-A1E11QM@ CW4L-A1E20QM@	\dashv
			2NC	CW1L-A1E20QM©	CW4L-A1E20QM©	-
			2NO-2NC	CW1L-A1E22QM@	CW4L-A1E22QM2	_
			1NO	CW1L-A1E10QM42	CW4L-A1E10QM42	
			1NC	CW1L-A1E01QM42	CW4L-A1E01QM42	
		230/240V AC	1NO-1NC	CW1L-A1E11QM4@	CW4L-A1E11QM42	
		230/240V AU	2N0	CW1L-A1E20QM42	CW4L-A1E20QM42	
			2NC	CW1L-A1E02QM42	CW4L-A1E02QM42	
			2NO-2NC	CW1L-A1E22QM42	CW4L-A1E22QM4@	

For more information, visit http://apac.idec.com

Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof**

Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator

Sensors AUTO-ID

ø16 ø22 ø30 Miniature Pilot Lights

LB LBW UP Flush Bezel

Illuminated Pushbuttons

Package quantity: 1

		Operating	Contact	Par	t No.	Illumination Color
Shape	Operation	Voltage	Configuration	Black Bezel	Metallic Bezel	Code ②
Round Extended			1NO	CW1L-M2E10Q2@	CW4L-M2E10Q2@	
CW□L-M2			1NC	CW1L-M2E01Q2@	CW4L-M2E01Q22	
CW□L-A2		6V AC/DC	1NO-1NC	CW1L-M2E11Q2@	CW4L-M2E11Q22	
		OV AC/DC	2N0	CW1L-M2E20Q2@	CW4L-M2E20Q2@	
			2NC	CW1L-M2E02Q2@	CW4L-M2E02Q22	
			2NO-2NC	CW1L-M2E22Q2@	CW4L-M2E22Q2©	
		12V AC/DC	1NO	CW1L-M2E10Q3@	CW4L-M2E10Q3@	
			1NC	CW1L-M2E01Q3@	CW4L-M2E01Q3@	_
			1NO-1NC	CW1L-M2E11Q3@	CW4L-M2E11Q3②	-
			2N0	CW1L-M2E20Q3@	CW4L-M2E20Q3②	
			2NC	CW1L-M2E02Q3② CW1L-M2E22Q3②	CW4L-M2E02Q3② CW4L-M2E22Q3②	
			2NO-2NC 1NO	CW1L-M2E10Q4@	CW4L-M2E10Q4@	
			1NC	CW1L-M2E01Q4@	CW4L-M2E01Q4@	
			1NO-1NC	CW1L-M2E11Q4@	CW4L-M2E11Q4@	Specify an
		24V AC/DC	2N0	CW1L-M2E20Q4@	CW4L-M2E20Q4@	illumination color code
			2NC	CW1L-M2E02Q4@	CW4L-M2E02Q42	place of ② in the Part N
			2NO-2NC	CW1L-M2E22Q42	CW4L-M2E22Q42	A: amber
	Momentary		1NO	CW1L-M2E10QH2	CW4L-M2E10QH2	G: green
			1NC	CW1L-M2E01QH2	CW4L-M2E01QH2	PW: pure white
_		100/100/140	1NO-1NC	CW1L-M2E11QH@	CW4L-M2E11QH2	R: red
		100/120V AC	2N0	CW1L-M2E20QH2	CW4L-M2E20QH2	S: blue Y: yellow
			2NC	CW1L-M2E02QH2	CW4L-M2E02QH2	i. yonow
			2NO-2NC	CW1L-M2E22QH ²	CW4L-M2E22QH2	_
			1NO	CW1L-M2E10QM2	CW4L-M2E10QM2	_
			1NC	CW1L-M2E01QM2	CW4L-M2E01QM2	
		200/220V AC	1NO-1NC	CW1L-M2E11QM ²	CW4L-M2E11QM2	
		200/2201710	2N0	CW1L-M2E20QM2	CW4L-M2E20QM2	
			2NC	CW1L-M2E02QM2	CW4L-M2E02QM2	
(black bezel)			2NO-2NC	CW1L-M2E22QM2	CW4L-M2E22QM2	
			1NO	CW1L-M2E10QM4©	CW4L-M2E10QM4©	
			1NC	CW1L-M2E01QM4@	CW4L-M2E01QM4@	
		230/240V AC	1NO-1NC 2NO	CW1L-M2E11QM4@ CW1L-M2E20QM4@	CW4L-M2E11QM42 CW4L-M2E20QM42	
			2NC	CW1L-M2E02QM4@	CW4L-M2E02QM4©	
			2NO-2NC	CW1L-M2E22QM4@	CW4L-M2E22QM4@	
			1NO	CW1L-A2E10Q2@	CW4L-A2E10Q2@	
0			1NC	CW1L-A2E01Q2@	CW4L-A2E01Q2@	
			1NO-1NC	CW1L-A2E11Q2@	CW4L-A2E11Q2@	
		6V AC/DC	2N0	CW1L-A2E20Q2@	CW4L-A2E20Q2@	
			2NC	CW1L-A2E02Q22	CW4L-A2E02Q22	
(metallic bezel)			2NO-2NC	CW1L-A2E22Q2@	CW4L-A2E22Q2@	
(metanic bezei)			1NO	CW1L-A2E10Q3@	CW4L-A2E10Q3@	
			1NC	CW1L-A2E01Q3@	CW4L-A2E01Q32	
		12V AC/DC	1NO-1NC	CW1L-A2E11Q3@	CW4L-A2E11Q3@	
		127 A0/D0	2N0	CW1L-A2E20Q3@	CW4L-A2E20Q3@	
			2NC	CW1L-A2E02Q3@	CW4L-A2E02Q3@	_
			2NO-2NC	CW1L-A2E22Q3②	CW4L-A2E22Q3©	_
See B-024 for replacement LED			1NO	CW1L-A2E10Q4@	CW4L-A2E10Q4@	4
modules.			1NC	CW1L-A2E01Q42	CW4L-A2E01Q4@	Specify an
Marking film can be inserted to indicate legends. See R-026		24V AC/DC	1NO-1NC	CW1L-A2E11Q4@	CW4L-A2E11Q4@	illumination color code
indicate legends. See B-026. See B-019 for dimensions.			2N0	CW1L-A2E20Q4@	CW4L-A2E20Q4@	in place of ② in the Part No.
A dummy block is installed when			2NC	CW1L-A2E02Q4@	CW4L-A2E02Q4@	i cirt ivU.
one contact block is used.	Maintained		2NO-2NC 1NO	CW1L-A2E22Q4@ CW1L-A2E10QH@	CW4L-A2E22Q4@ CW4L-A2E10QH@	A: amber
			1NC	CW1L-A2E10QH@ CW1L-A2E01QH@	CW4L-A2E10QH@	G: green
			1NO-1NC	CW1L-A2E11QH2	CW4L-A2E11QH@	PW: pure white
		100/120V AC	2N0	CW1L-A2E20QH2	CW4L-A2E20QH2	R: red S: blue
			2NC	CW1L-A2E02QH2	CW4L-A2E02QH@	Y: yellow
			2NO-2NC	CW1L-A2E22QH2	CW4L-A2E22QH2	–
			1NO	CW1L-A2E10QM@	CW4L-A2E10QM@	\dashv
			1NC	CW1L-A2E01QM2	CW4L-A2E01QM@	
			1NO-1NC	CW1L-A2E11QM2	CW4L-A2E11QM@	7
		200/220V AC	2NO	CW1L-A2E20QM2	CW4L-A2E20QM2	7
			2NC	CW1L-A2E02QM2	CW4L-A2E02QM2	7
			2NO-2NC	CW1L-A2E22QM ²	CW4L-A2E22QM2	7
			1NO	CW1L-A2E10QM4@	CW4L-A2E10QM42	
			1NC	CW1L-A2E01QM4@	CW4L-A2E01QM42	
		220/2404 40	1NO-1NC	CW1L-A2E11QM42	CW4L-A2E11QM4@	
		230/240V AC	2N0	CW1L-A2E20QM4@	CW4L-A2E20QM4@	
			2NC	CW1L-A2E02QM4@	CW4L-A2E02QM42	
			2110	OTT TELEGRAM TO	OT IL TILLOLGIII TO	

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors AUTO-ID

Ø16Ø22Ø30MiniaturePilot Lights

Control Boxes

Emergency
Stop Switches
Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Pilot Lights

Package quantity: 1

			Part	! No.	Package quantity:
	Shape	Operating Voltage	Black Bezel	Metallic Bezel	Illumination Color Code ②
	Round Flush CW□P-1	6V AC/DC	CW1P-1EQ2@	CW4P-1EQ2®	
		12V AC/DC	CW1P-1EQ3@	CW4P-1EQ3@	
-	(black bezel)	24V AC/DC	CW1P-1EQ4@	CW4P-1EQ4@	A: amber G: green PW: pure white
-		100/120V AC	CW1P-1EQH@	CW4P-1EQH@	R: red S: blue Y: yellow
-		200/220V AC	CW1P-1EQM@	CW4P-1EQM@	
-	(metallic bezel)	230/240V AC	CW1P-1EQM4©	CW4P-1EQM4@	
-	Round Extended CW□P-2	6V AC/DC	CW1P-2EQ2@	CW4P-2EQ2@	
-		12V AC/DC	CW1P-2EQ3@	CW4P-2EQ3@	
	(black bezel)	24V AC/DC	CW1P-2EQ4@	CW4P-2EQ4@	A: amber G: green PW: pure white
		100/120V AC	CW1P-2EQH@	CW4P-2EQH@	R: red S: blue Y: yellow
-		200/220V AC	CW1P-2EQM@	CW4P-2EQM@	
-	(metallic bezel)	230/240V AC	CW1P-2EQM4@	CW4P-2EQM4@	

- \bullet Specify an illumination color code in place of ${\mathbin{@}}$ in the Part No.
- See B-019 for dimensions.
- See B-024 for replacement LED modules.
- Two dummy blocks are installed.

CW	
LW-F	
LB	
LBW	
UP	
Flush Bezel	

Pushbuttons

					Package quantity: 1	흦
Shape	Operation	Contact	Pa	rt No.	Button Color Code ①	ot Lights
·	Орстаноп	Configuration	Black Bezel	Metallic Bezel	Dutton color code o	Ints
Round Flush CW□B-M1		1NO	CW1B-M1E10①	CW4B-M1E10①		
CW□B-A1		1NC	CW1B-M1E01①	CW4B-M1E01①		
		1NO-1NC	CW1B-M1E11①	CW4B-M1E11①		APEM
		2N0	CW1B-M1E20①	CW4B-M1E20①	B: black G: green	Switches & Pilot Lights
	Momentary	2NC	CW1B-M1E02①	CW4B-M1E02①	G: green R: red	Control Boxes
	Wiomentary	2NO-1NC	CW1B-M1E21①	CW4B-M1E21®	S: blue W: white	Emergency
		1NO-2NC	CW1B-M1E12①	CW4B-M1E12①	Y: yellow	Stop Switches
(black bezel)		3NO	CW1B-M1E30①	CW4B-M1E30①		Enabling Switches
(======)		3NC	CW1B-M1E03①	CW4B-M1E03①		Safety Products
		2NO-2NC	CW1B-M1E22①	CW4B-M1E22①		Explosion Proof
		1NO	CW1B-A1E10①	CW4B-A1E10①		Terminal Blocks
		1NC	CW1B-A1E01①	CW4B-A1E01①	B: black	
		1NO-1NC	CW1B-A1E11①	CW4B-A1E11①	G: green R: red	Relays & Sockets
	Maintained	2N0	CW1B-A1E20①	CW4B-A1E20①	S: blue	Circuit Protectors
(metallic bezel)		2NC	CW1B-A1E02①	CW4B-A1E02①	W: white Y: yellow	Power Supplies
		2NO-2NC	CW1B-A1E22①	CW4B-A1E22①		LED Illumination
Round Extended		1NO	CW1B-M2E10①	CW4B-M2E10①		
CW□B-M2 CW□B-A2		1NC	CW1B-M2E01①	CW4B-M2E01®		Operator Controllers
		1NO-1NC	CW1B-M2E11①	CW4B-M2E11①		Interfaces
		2N0	CW1B-M2E20①	CW4B-M2E20①	B: black	Sensors
		2NC	CW1B-M2E02①	CW4B-M2E02①	G: green R: red	AUTO-ID
	Momentary	2NO-1NC	CW1B-M2E21①	CW4B-M2E21①	S: blue	
		1NO-2NC	CW1B-M2E12①	CW4B-M2E12①	W: white Y: yellow	
41.11.5		3N0	CW1B-M2E30①	CW4B-M2E30①		Flush Silhouette
(black bezel)		3NC	CW1B-M2E03①	CW4B-M2E03①		
		2NO-2NC	CW1B-M2E22①	CW4B-M2E22①		ø16 ————————————————————————————————————
		1NO	CW1B-A2E10①	CW4B-A2E10①		ø22
		1NC	CW1B-A2E01①	CW4B-A2E01①	B: black	ø30
		1NO-1NC	CW1B-A2E11①	CW4B-A2E11①	G: green R: red	Miniature
	Maintained	2N0	CW1B-A2E20①	CW4B-A2E20①	S: blue	Pilot Lights
		2NC	CW1B-A2E02①	CW4B-A2E02①	W: white Y: yellow	i ilut Ligitta
(metallic bezel)		2NO-2NC	CW1B-A2E22①	CW4B-A2E22①	, , , , , , , , , , , , , , , , , ,	
<u> </u>						

- \bullet Specify a button color code in place of $\textcircled{\scriptsize 1}$ in the Part No.
- See B-020 for dimensions.
- Two or one dummy block is installed when one or two contact blocks are used, respectively.
 Contact configurations 2NO-1NC, 1NO-2C, 3NO, and 3NC are available for momentary pushbuttons only.

LB LBW UP

Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof** Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator

> Sensors AUTO-ID

ø16 ø22 ø30 Miniature Pilot Lights

> LW-F LB LBW

> > UP

Flush Bezel

Selector Switches

Package quantity: 1

	cw□s								Package quantity:	
Shape	(Knob O)	perator)				(black beze	el)	meta	llic bezel)	
	Cor	ntact	Contact	Block		Operator	r Position		L, +>R	
No. of Po	sitions Config	juration ode)	Mounting Position	Con	tact	L	R	L R Maintained	Spring return from right	
	11	NO	1	N	0		•			
	(1	10)	2	_			nmy	CW□S-2E10	CW□S-21E10	
-			3	-			nmy			
f	1	NC	1	-	_		nmy	CWEIG 2F01	CWEIC 21F01	
=		01)	3	- N	iC	Dur	nmy	CW□S-2E01	CW□S-21E01	
_			1	N						
3		-1NC	2	_	_	Dur	nmy	CW□S-2E11	CW□S-21E11	
t	(1	11)	3	N	С	•	,		3	
8				N			•			
_	2	NO 20)	2	_	_	Dur	nmy	CW□S-2E20	CW□S-21E20	
۱	(2	(20)	3	N	0		•			
5	2112	NC	1	N	С	•				
_ r	(0	(02)	2	-	_	Dur	nmy	CW□S-2E02	CW□S-21E02	
<u>s</u>			3	NC		•				
3	2N0	-1NC		1 NO			•	011120 0504	011120 04504	
_)		21)	2	N		•	•	CW□S-2E21	CW□S-21E21	
90° 2-po:	eition		3	NC NO			•			
30 Z-po	1NO	-2NC	2	N		•		CW□S-2E12	CW□S-21E12	
	(1	12)	3	N		-		OWEG ZETZ	∩M□2-51F15	
			1	N			•			
5	3	NO 30)	2	N			•	CW□S-2E30	CW□S-21E30	
_	,	30)	3	N	0		•			
2		NO	1	N		•				
)	3 ((NC 03)	2	N		•		CW□S-2E03	CW□S-21E03	
-	`		3		С	•	_			
-			1	NO/ NC	NO NC	•	•			
<u> </u>	2N0	2NO-2NC		_	' 		nmy	CW□S-2E22	CW□S-21E22	
	(22)		2	NO/	NO		•			
			3	NC	NC	•				
,			1	2N0	NO		•			
	4	NO		ZINU	NO		•			
	4 (4	NO 40)	2	_	_]	Dur	nmy	CW□S-21E40	CW□S-21E40	
3	,	,	3	2N0	NO		•			
					NO		•			

- Specify a bezel color code in place of □ in the Part No.: 1 (black bezel), 4 (metallic bezel)
- Lever operator is also available. For dimensions, see B-010.
- When ordering a lever operator selector switch, designate L before E in the Part No. of knob operator selector switches.

[Example] CW1S-2E10 \rightarrow CW1S-2<u>L</u>E10

Lever Operator

Knob Operator Lever Operator

CW1S-*LE (black bezel)



CW4S-*LE (metallic bezel)

Contact Block Mounting Position



Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof**

Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator

Sensors AUTO-ID

ø16 ø22 ø30 Miniature Pilot Lights

LB LBW UP

Flush Bezel

Package quantity: 1

No. of	Contact	Contact	t Block		perato		L C R	L C R	L C R	Package quantity: 1
Positions	Configuration (Code)	Mounting Position	Contact	L	С	R	Maintained	Spring return from right	Spring return from left	Spring return two-way
	1NO-1NC (11)	1 2 3	NO — NC		Dumm	y	CW□S-3E11	CW□S-31E11	CW□S-32E11	CW□S-33E11
	1NO-1NC (11N1)	1 2 3	NC — NO		Dumm	y	CW□S-3E11N1	CW□S-31E11N1	CW□S-32E11N1	CW□S-33E11N1
	1NO-1NC (11N2)	1 2 3	NO NC	•	• Dumm		CW□S-3E11N2	CW□S-31E11N2	CW□S-32E11N2	CW□S-33E11N2
	1NO-1NC (11N3)	1 2 3	NC NO		Dumm		CW□S-3E11N3	CW□S-31E11N3	CW□S-32E11N3	CW□S-33E11N3
	1NO-1NC (11N4)	1 2 3	NO NO NC	•	Dumm	y	CW□S-3E11N4	CW□S-31E11N4	CW□S-32E11N4	CW□S-33E11N4
	2NO (20)	1 2 3	NO NO		Dumm	y •	CW□S-3E20	CW□S-31E20	CW□S-32E20	CW□S-33E20
	2N0 (20N1)	1 2 3	NO NO	•	Dumm	_	CW□S-3E20N1	CW□S-31E20N1	CW□S-32E20N1	CW□S-33E20N1
	2NC (02)	1 2 3	NC — NC		Dummy		CW□S-3E02	CW□S-31E02	CW□S-32E02	CW□S-33E02
	2NC (02N1)	1 2 3	NC NC		Dumm	y	CW□S-3E02N1	CW□S-31E02N1	CW□S-32E02N1	CW□S-33E02N1
45°	2NO-1NC (21)	1 2 3	NO NO NC	•			CW□S-3E21	CW□S-31E21	CW□S-32E21	CW□S-33E21
3-position	2NO-1NC (21N1)	1 2 3	NO NC NO	•			CW□S-3E21N1	CW□S-31E21N1	CW□S-32E21N1	CW□S-33E21N1
	1NO-2NC (12)	1 2 3	NO NC NC	•	•		CW□S-3E12	CW□S-31E12	CW□S-32E12	CW□S-33E12
	1NO-2NC (12N1)	1 2 3	NC NO NC	•			CW□S-3E12N1	CW□S-31E12N1	CW□S-32E12N1	CW□S-33E12N1
	3NO (30)	1 2 3	NO NO NO	•		•	CW□S-3E30	CW□S-31E30	CW□S-32E30	CW□S-33E30
	3NC (03)	1 2 3	NC NC				CW□S-3E03	CW□S-31E03	CW□S-32E03	CW□S-33E03
	2NO-2NC (22)	1 2	NO/ NC NC		Dumm	у	CW□S-3E22	CW□S-31E22	CW□S-32E22	CW□S-33E22
		3	NO/ NO NC NC 2NO NO	•			-			
	4NO (40)	2	2NO NO NO NO NO		Dumm	у	CW□S-3E40	CW□S-31E40	CW□S-32E40	CW□S-33E40
	2NO-2NC	1 2	2NC NC NC	Г	Dumm		CW□S-3E22N2	CW□S-31E22N2	CW□S-32E22N2	CW□S-33E22N2
	(22N2)	3	2N0 NC	_ L	Jamill	• •		OTTEN OF OTTER ONLY	OTTLO-OZEZZINZ	OTT LIO-JULEZINZ

[•] Specify a bezel color code in place of ☐ in the Part No.: 1 (black bezel), 4 (metallic bezel) • For the contact block mounting position, see B-015.

[Example] CW1S-3E11 \rightarrow CW1S-3LE11

Knob Operator Lever Operator



[•]Lever operator is also available. For dimensions, see B-021.

[•]When ordering a lever operator selector switch, designate L before E in the Part No. of knob operator selector switches.

Key Selector Switches

Package quantity: 1

으								rackaye quantity. I						
ot Lights	Shape	CW□K	/□K											
APEM			(black bezel) (metallic bezel)											
Switches & Pilot Lights		Contact	Contac				L R	L TR						
Control Boxes	No. of Positions	Configuration (Code)	Mounting Position	Contact	L	R	Maintained	Spring return from right						
Emergency Stop Switches		1NO	1	NO		I								
Enabling		(10)	2	_	Dun		CW□K-2AE10	CW□K-21BE10						
Switches			3	_	Dun									
Safety Products		1NC	1	_	Dun									
Explosion Proof		(01)	2		Dun	nmy	CW□K-2AE01	CW□K-21BE01						
Explosion 1 1001			3	NC NO	•									
Terminal Blocks		1NO-1NC	1 2	NO	Dun	• ·	CW□K-2AE11	CWITH OIDEII						
Relays & Sockets		(11)	3	NC NC	Duli	iiiiy	- GWLIK-ZAETT	CW□K-21BE11						
Circuit			1	NO										
Protectors		2N0	2	_	Dun		CW□K-2AE20	CW□K-21BE20						
Power Supplies		(20)	3	NO		•								
		aua.	1	NC	•									
LED Illumination		2NC (02)	2	_	Dun	nmy	CW□K-2AE02	CW□K-21BE02						
Controllers		(/	3	NC	•									
Operator		2NO-1NC	1	NO		•								
Interfaces		(21)	2	NO		•	CW□K-2AE21	CW□K-21BE21						
Sensors	90° 2-position		3	NC NO	•									
		1NO-2NC	2	NO NC	•	•	CW□K-2AE12	CW□K-21BE12						
AUTO-ID		(12)	3	NC NC			GWLIK-ZAETZ	GWLIK-ZIDEIZ						
			1	NO NO										
		3NO	2	NO		•	CW□K-2AE30	CW□K-21BE30						
Flush Silhouette		(30)	3	NO		•								
Flusii Siiilouette		2112	1	NC	•									
ø16		3NC (03)	2	NC	•		CW□K-2AE03	CW□K-21BE03						
ø22		(55)	3	NC	•									
			1	NO/NC NO NC	•	•								
ø30		2NO-2NC (22)	2		Dun	nmy	CW□K-2AE22	CW□K-21BE22						
Miniature			3	NO/NC NO NC	•	•								
Pilot Lights		4NO	1	2NO NO NO		•								
		4NO (40)	2	_	Dun	nmy	CW□K-2AE40	CW□K-21BE40						
	(40)		3	2NO NO		•	_							

- Specify a bezel color code in place of □ in the Part No.: 1 (black bezel), 4 (metallic bezel)
- On the spring-returned types, the key can be released only from the maintained position. On the maintained types, the key can be released from every position. Key retained positions are also available. See below.
- Two keys are supplied. Key cylinder material: Metal
- Besides the standard key (key number OH), six other keys are also available. See below.
- For the contact block mounting position, see B-018. For dimensions, see B-022.
- When ordering an optional key or optional key retained positions, specify designation codes as shown below:

[Example] CW1K-2AE10-1H

_ (blank): Standard key (0H, reversible) 1H to 2H: Reversible key 3H to 6H: Non-reversible key

Key number is indicated on the key cylinder. Standard keys do not have a key number indication.

Key removal position code

2-position

Removable in all positions Removable in left only Removable in right only

2N0

NO

3-position

- Removable in all positions Removable in left and center
- Removable in right and center
- Removable in center only
- Removable in right and left
- Removable in left only
- Removable in right only

Note: Key is retained in the spring-returned position.

LW-F

LB

LBW

UP

Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof** Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator

Sensors AUTO-ID

ø16 ø22 ø30 Miniature Pilot Lights

LB LBW UP Flush Bezel

Package quantity: 1

				Operato	nr				Package quantity	
No. of	Contact	Conta	ct Block	Position		L C R	L C R	L C R	L C R	
ositions	Configuration	Mounting Position	Contact	L C	R	Maintained	Spring return from right	Spring return from left	Spring return two-way	
	1NO-1NC	1	NO	•						
	(11)	2		Dumm	ıy	CW□K-3AE11	CW□K-31BE11	CW□K-32CE11	CW□K-33DE11	
		3	NC							
	1NO-1NC	1	NC	Diverse		000000000000000000000000000000000000000	OWEN 04 DE44N4	00054404	OMEN CODES	
	(11N1)	3	NO	Dumm	iy •	CW□K-3AE11N1	CW□K-31BE11N1	CW□K-32CE11N1	CW□K-33DE11N1	
		1	NO NO							
	1NO-1NC	2	NC			CW□K-3AE11N2	CW□K-31BE11N2	CW□K-32CE11N2	CW□K-33DE11N2	
	(11N2)	3	_	Dumm	IV	OWER OALTINE	OWER OTBETTIVE	OWER OZOETINZ	OWER CODETINE	
		1		Dumm						
	1NO-1NC	2	NC	•	ĺ	CW□K-3AE11N3	CW□K-31BE11N3	CW□K-32CE11N3	CW□K-33DE11N3	
	(11N3)	3	NO							
	1110 1110	1	_	Dumm	ıy					
	1NO-1NC (11N4)	2	NO	•		CW□K-3AE11N4	CW□K-31BE11N4	CW□K-32CE11N4	CW□K-33DE11N4	
	(,	3	NC							
	2N0	1	NO NO							
	(20)	2		Dumm	ıy	CW□K-3AE20	CW□K-31BE20	CW□K-32CE20	CW□K-33DE20	
	(20)	3	NO							
	ONO (001/4)	1		Dumm	<u> </u>	OWER CARCOLL	OMEN CARECONA	OWEN COOFFEET	OWEN COSTO	
	2NO (20N1)	3	NO NO			CW□K-3AE20N1	CW□K-31BE20N1	CW□K-32CE20N1	CW□K-33DE20N1	
		1	NC NC						_	
	2NC	2	INC	Dumm	ıv	CW□K-3AE02	CW□K-31BE02	CW□K-32CE02	CW□K-33DE02	
	(02)	3	NC	Dullilli	i y	GWLIK-SAEUZ	GWLIK-SIDEUZ			
		1	_	Dumm	ıv			CW□K-32CE02N1	CW□K-33DE02N1	
	2NC (02N1)	2	NC		· ,	CW□K-3AE02N1	CW□K-31BE02N1			
	(,	3	NC			OWER GREEK	ON ENCORPERENT	OWER SESECTION	OWER CODECENT	
		1	NO NO	•						
F0	2NO-1NC (21)	2	NO	•		CW□K-3AE21	CW□K-31BE21	CW□K-32CE21	CW□K-33DE21	
5° -position		3	NC							
position	2NO-1NC	1	NO						CW□K-33DE21N1	
	(21N1)	2	NC	•		CW□K-3AE21N1	CW□K-31BE21N1	CW□K-32CE21N1		
	\	3	NO NO		•					
	l	1	NO				CW□K-31BE12		CW□K-33DE12	
	1NO-2NC (12)	2	NC			CW□K-3AE12		CW□K-32CE12		
		3	NC							
	1NO-2NC	2	NC NO			CW□K-3AE12N1	CW□K-31BE12N1	CW□K-32CE12N1	CW□K-33DE12N1	
	(12N1)	3	NC NC			OWEN-SWEIZINI	OWEN-SIDEIZNI	OWEN-320E1ZIVI	OWEN-33DETSN1	
		1	NO NO	7						
	3NO	2	NO NO		•	CW□K-3AE30	CW□K-31BE30	CW□K-32CE30	CW□K-33DE30	
	(30)	3	NO		Ŏ	3.1.2.1.371200	3.1.2.1. 3.15.20	3	0.1.2.1. 000200	
	2112	1	NC							
	3NC (03)	2	NC	•		CW□K-3AE03	CW□K-31BE03	CW□K-32CE03	CW□K-33DE03	
	(00)	3	NC							
		1	NO/NC NO	•						
	2NO-2NC		NC NC	Di ima iii		OWER 64500	OMEN OFF	OWEN 000500	OWEN CORECO	
	(22)	2	NO NO	Dumm	ly •	CW□K-3AE22	CW□K-31BE22	CW□K-32CE22	CW□K-33DE22	
		3	NO/NC NC			-				
			NO							
	450	1	2NO NO	Ŏ	L]				
	4NO (40)	2		Dumm	ıy	CW□K-3AE40	CW□K-31BE40	CW□K-32CE40	CW□K-33DE40	
	[3	2NO NO		•					
		-	NO		_			-		
		1	2NC NC							
	2NO-2NC	2	NC	Dumm	ıv	CW□K-3AE22N2	CW□K-31BE22N2	CW□K-32CE22N2	CW□K-33DE22N2	
	(22N2)		avo NO	Julilli	•	JAN TIV-DWITTING	SWEIK-SIDEZZIVZ	OWEN-020L22N2	OWEN JODEZZINZ	
	1	3	2N0 N0		ŏ	1				

• Specify a bezel color code in place of □ in the Part No.: 1 (black bezel), 4 (metallic bezel)

• On the spring-returned types, the key can be released only from the maintained position. On the maintained types, the key can be released from every position. Key retained positions are also available. See B-010.

• Two keys are supplied. • Key cylinder material: Metal

• Besides the standard key (key number 0H), six other keys are also available. See B-010.

• For the contact block mounting position, see right.

• For dimensions, see B-022.

Contact Block Mounting Position




All dimensions in mm.

Illuminated Pushbuttons

1 to 2 contacts

Dimensions

Round Flush



Control Boxes

Switches

APEM

Emergency Stop Switches Enabling

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets Circuit Protectors

Power Supplies

LED Illumination

Controllers Operator

Interfaces Sensors

AUTO-ID

ø16

ø22


ø30

Miniature


Pilot Lights


LW-F

Round Extended





Round Flush






Round Extended






Pilot Lights Round Flush



Round Extended




See B-008 for mounting hole layout.


All dimensions in mm. **Pushbuttons**

1 to 3 contacts


Round Flush




Round Extended



4 contacts **Round Flush**



Round Extended



See B-008 for mounting hole layout.

APEM

Control Boxes

Emergency Stop Switches

Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

ø16

ø22 ø30

Miniature

Pilot Lights

LB LBW

UP

All dimensions in mm.

Selector Switches

39.9

4 contacts

Knob Operator

2nd-tier contact block (NC)

M3.5 Terminal Screw

13.1


1st-tier contact block (NO)

30


Panel Thickness 0.8 to 3.2

1 to 3 contacts

Knob Operator



Lever Operator



Control Boxes Emergency Stop Switches Enabling

Switches

APEM

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets Circuit Protectors

Power Supplies

LED Illumination

Controllers Operator

Interfaces Sensors

AUTO-ID

ø16 ø22

ø30

LW-F


LB LBW UP Flush Bezel


Miniature Pilot Lights


Operator Angle Locking Ring 2.5 13.1 59.9

0.5

Lever Operator








See B-008 for mounting hole layout.

All dimensions in mm.

Key Selector Switches

1 to 3 contacts









Key No: 3H to 6H (non-reversible key)

Keys


Reversible Key



Non-reversible Key



4 contacts



Key No: 3H to 6H (non-reversible key)

See B-008 for mounting hole layout.

APEM

Control Boxes

Emergency Stop Switches

Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks Relays & Sockets

Circuit

Protectors

Power Supplies LED Illumination

Controllers Operator

Interfaces Sensors

AUTO-ID

ø16

ø22

ø30 Miniature

Pilot Lights

LB

LBW

UP

Circuit
Protectors

Power Supplies

LED Illumination

Controllers

Operator

Sensors AUTO-ID

Ø16Ø22Ø30MiniaturePilot Lights

LW-F LB LBW

Flush Bezel

Control Boxes

Emergency
Stop Switches
Enabling
Switches

Safety Products

Explosion Proof

Terminal Blocks

Accessories

Shape	Shape M		Part No.	Package Quantity	Remarks
Locking Ring Wrench		Metal (Brass)	MW9Z-T1	1	Used to tighten the locking ring when installing the CW series control unit in a panel cut-out. Weight: Approx 150 g 110
Mounting Hole Plug		Polyamide (black)	LW9Z-BP1	1	Used to plug an unnecessary ø22.3 mm hole in the panel. Degree of protection: IP65 Panel thickness: 0.8 to 6.0 mm Panel Thickness 0.8 to 6.0 mm
			CW9Z-D11	1	Degree of protection: IP66/67 UL Type 4X Panel thickness: 0.8 to 3.2 mm Use with round extended illuminated pushbuttons/pushbuttons.
21			CW9Z-D12	1	Degree of protection: IP66/67 UL Type 4X Panel thickness: 0.8 to 3.2 mm Use with round extended illuminated pushbuttons/pushbuttons.

Nameplates

Description		Material	Ordering No.	Package Quantity	Dimensions (mm)	
	Legend	Waterial	Ordering No.	I dokage Quantity	Difficiations (fillit)	
CWAM	Order marking plate (HWNP) separately.	Plastic (black)	CWAM	1	Marking plate HWNP is necessary. Degree of protection: IP65 Do not remove the gasket on the operator. 29 27	

Note: Cannot be used with HW/FB series control box types.

Making Plate

Description	Material	Part No.	Ordering No.	Package Quantity	Dimensions (mm)
HAND AUTO	Aluminum (black)	LIWND [HWNP-□	1	White legend on black background. Engraving area: W25, H7
Image: HWNP-35	1.0 mm thick	HWNP-□	HWNP-□PN10	10	≅\rightarrow\rightarr

 $[\]bullet$ Specify a legend code in place of \square in the Ordering No.

Legends

Code	Legend	Code	Legend
0	(blank)	4	ST0P
1	ON	31	OFF-ON
2	0FF	35	HAND-AUTO
3	START	53	HAND-OFF-AUTO

For more information, visit http://apac.idec.com

Control Boxes Emergency Stop Switches Enabling Switches Safety Products **Explosion Proof**

Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator

Sensors AUTO-ID

ø16 ø22 ø30 Miniature Pilot Lights

LB LBW UP

Flush Bezel

Maintenance Parts

Used for replacement only. Do not use the maintenance parts to remodel or expand the CW series control units.

Shape		Material	Part No.	Ordering No.	Package Quantity	Remarks	
Button 2	1 For round flush	Polyarylate ø19.5 H3.5	CW9Z-B11①	CW9Z-B11①PN05	5	For maintained pushbuttons. Specify a button color code in place of ① in the Part No. B (black), G (green), R (red), S (blue), W (white Y (yellow)	
	2 For round extended	Polyarylate ø19.5 H6.2	CW9Z-B12①	CW9Z-B12①PN05	5		
Lens 2	1 Round Flush	Polyalylate	CW9Z-L11@-K	CW9Z-L11@-KPN05	5	Color code ②: A (amber), C (clear), G (green), R (red), S (blue), Y (yellow) Use a clear (C) lens for pure white (PW)	
	2 Round Extended	Polyalylate	CW9Z-L12@-K	CW9Z-L12@-KPN05	5	illumination. 1: For illuminated pushbutton, pilot light 2: For illuminated pushbutton	
1 3	3 Round Extended	Polyalylate	CW9Z-L15@-K	CW9Z-L15@-KPN05	5	3: For pilot light	
Single Contact Block Push rod	Housing	1NO	YW-E10R	YW-E10R	1	Push rod color: black Housing color: blue and black Terminal No.: 3-4	
	nousing	1NC	YW-E01	YW-E01	1	Push rod color: red Housing color: reddish purple Terminal No.: 1-2	
Double Contact Block	(2NO	YW-EW2R0	YW-EW2R0	1	Push rod color: black Housing color: blue and black Terminal No. 1st tier: 13-14 2nd tier: 23-24	
Push rod Housing		2NC	YW-EW02	YW-EW02	1	Push rod color: red Housing color: reddish purple Terminal No. 1st tier: 11-12 2nd tier: 21-22	
(photo: YW-EW1R1)		1NO, 1NC	YW-EW1R1	YW-EW1R1	1	Push rod color: gray Housing color: reddish purple/blue Terminal No. 1st tier: 13-14 2nd tier: 21-22	
Dummy Block		Polyamide (black)	CW-DB	CW-DBPN05	5		
Locking Ring		Polyamide (black)	CW9Z-LN	CW9Z-LNPN05	5		
Gasket					Waterproof gasket between CW control unit bezel and the mounting panel.		
		Nitrile rubber CW9Z-WM		CW9Z-WMPN10	10	# 10 6 5 10 10 10 10 10 10 10 10 10 10 10 10 10	
Spare Key Non-reversible Reversible		Zinc	LA9Z-SK-0H	LA9Z-SK-0HPN02	2	Specify a key No. in place of □. OH: Standard key (reversible) 1H to 2H: Reversible key	
		(nickel-plated)	LA9Z-SK-□	LA9Z-SK-□PN02		3H to 6H: Non-reversible key For dimensions, see B-022.	

LED Module

Package quantity: 1

					i donago quantity. I
	Shape	Operating Voltage Range	Current Draw	Part No.	Illumination Color Code ②
		6V AC/DC ±10%	15 mA	CW-EAQ22	Specify an illumination color code in place
	747.22	12V AC/DC ±10%	15 mA	CW-EAQ32	of ② in the Part No.
	Tion	24V AC/DC ±10%	16.5 mA	CW-EAQ42	A: amber
	200	100/120V AC ±10%	18 mA	CW-EAQH2	G: green PW: pure white
	豊富さ	200/220V AC ±10%	20 mA	CW-EAQM2	R: red
		230/240V AC ±10%	18 mA	CW-EAQM42	S: blue

[•] Use a pure white (PW) LED module for yellow (Y) illumination.

\triangle

Safety Precautions

- Turn off the power to the CW series control units before installation, removal, wiring, and maintenance. Failure to turn power off may cause electrical shocks or fire hazard.
- For wiring, use wires of a proper size to meet the voltage and current requirements. Tighten the M3.5 terminal screws to a tightening torque of 1.0 to 1.3 N·m. Failure to tighten the terminal screws may cause overheating and fire.

APEM

Pilot Lights

Control Boxes

Emergency Stop Switches Enabling

Switches

Safety Products

Explosion Proof

Terminal Blocks

Circuit

Protectors
Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette

ø16

ø22

ø30

Miniature

Pilot Lights

CW

LW-F

LB

LBW

UP

Flush Bezel

Operating Instructions

Notes for Operation

 When using the CW series control units in a safetyrelated circuit of a control system, observe safety rules and regulations of each country concerning particular applications of the actual machines and facilities. Perform risk assessment before operation to ensure safety.

Operating Conditions

- In corrosive gas or high-temperature, high-humidity atmosphere, contact failure due to corrosion or color change or breakage of the housing may occur.
- Main parts of the CW series control units are made of plastics. Do not scratch the surface with a sharp object or apply excessive shocks or load, otherwise the control units may be damaged. In particular, keep the button, lens, and bezel from such damage, otherwise appearance and function may be impaired.
- Do not apply detergents, cutting oils, or chemicals which may impair the function and appearance of the CW series control units.

Removing and Installing the Contact Unit

 To remove the contact block from the operator, push the yellow locking lever and turn it to the left.



To install, align the TOP marking on the operator with the TOP marking on the contact block mounting adaptor, and turn the locking lever to the right.

Panel Mounting


Remove the contact block from the operator. Remove the locking ring from the operator. Insert the operator into the panel cut-out from the front, tighten the locking ring from the back, then install the contact block to the operator.

Installation in Panel Cut-out

Remove the locking ring from the operator. With the anti-rotation projection on the operator aligned with the recess in the mounting hole, insert the operator into the mounting hole. Tighten the locking ring from the rear of the panel.

Note for Panel Mounting

When installing the operator in a panel cut-out, use the optional locking ring wrench (MW9Z-T1) to tighten the locking ring to a recommended tightening torque of 1.2 N·m. Do not use pliers and do not tighten excessively, otherwise the operator may be damaged.



Mounting Hole

- 1. Mounting hole dimensions are in compliance with IEC 60947-5-1.
- If the anti-rotation projection is removed from the bezel, CW series control units can be mounted in ø22.3 mm mounting holes. To remove the anti-rotation projection, remove the gasket and use cutting pliers to break the projection.



Operating Instructions

Pushbuttons (momentary)


Momentary pushbutton caps cannot be removed. Do not tamper with the pushbutton caps using a screwdriver or pliers, otherwise the pushbutton caps may be damaged.

Pushbuttons (maintained) / Illuminated Pushbuttons / Pilot Lights Removing the button/lens


To remove the button or lens from a pushbutton, illuminated pushbutton or pilot light, insert a flat screwdriver under the flange of the lens at 90° from the TOP marking and twist the screwdriver.

Do not insert the screwdriver too deeply and do not apply excessive force to the lens, otherwise the bezel surface may be damaged.

[Screwdriver Insertion Direction]




[Screwdriver Insertion Angle]



Installing the Lens

Turn the groove in the lens to the TOP marking on the operator housing. With the groove aligned with the ridge, press the lens in.



Marking

Marking plates are not available for CW series illuminated pushbuttons and pilot lights. Marking film can be inserted to indicate legends.

Applicable Marking Film Size

Illuminated Pushbutton (Round Flush) Pilot Light (Round Flush, Round Extended)	Illuminated Pushbutton (Round Extended)		
13.8	12.6		


Thickness: 0.2 mm maximum Film material: Polyester (recommended)

Note: Film is not supplied and must be prepared by the user.

Installing the Rubber Boot

When using in places where the switches are subjected to water splash or an excessive amount of dust, make sure to use the optional rubber boot. Remove the gasket from the operator, and mount the rubber boot to cover the bezel. Make sure that the rubber boot is properly fitted, otherwise, the waterproof and dustproof characteristics are not ensured.

How to Install the Rubber Boot



Note: Install the rubber boot before mounting the unit to the panel.

Maintained Switches

Do not replace the button/lens while the operator is latched. Otherwise the internal structure will be damaged.

Selector Switches

Turn the selector operator or key to the detent positions.

Key Selector Switches

To prevent malfunctions and damage, take the following precautions.

- Insert the key to the bottom before turning.
- . Do not remove the key while turning.
- · Besides the standard key (OH), six other keys are available. Use a key with a key selector switch of a matching number indicated on the key cylinder. Standard key does not have a key number indication.
- Keys are available in two shapes. Key numbers 0H (standard), $\dot{1}\text{H}$, and 2H are reversible keys. Key numbers 3H, 4H, 5H, and 6H are non-reversible keys. Make sure of correct insertion direction.

APEM

Control Boxes

Emergency Stop Switches Enabling

Switches

Safety Products

Explosion Proof

Terminal Blocks Relays & Sockets

Circuit

Protectors Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

ø16

ø22

ø30

Miniature Pilot Lights

ΙR LBW

ПP

Control Boxes

Stop Switches

Safety Products

Explosion Proof

Terminal Blocks
Relays & Sockets

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Circuit Protectors

Enabling Switches

ø22 Flush Silhouette Switches CW Series

Contact Blocks and LED Modules

To remove the contact block from the operator, insert a flat screwdriver under the latch and push down the screwdriver as shown below. Before removing the LED module, first remove all contact blocks, and remove the LED module in the same manner.






Nameplate / Marking Plate


• Installing the marking plate on a nameplate



 To remove the marking plate, insert the flat screwdriver between the marking plate and nameplate.



Note: When using a nameplate, the mounting panel thickness is 2.6 mm maximum.



Wiring

Applicable Wires


Stranded wire: 2.0 mm² maximum (14AWG)
Solid wire: ø1.6 mm maximum (16AWG)
One or two wires can be connected to the terminal.

Applicable Crimping Terminals

[Spade terminal]


When using crimping terminals, be sure to use insulating tubes or use insulated crimping terminals.

Note: Ring terminals cannot be used.



[Ferrule]

When connecting two ferrules to one terminal, use ferrules without insulation.



When using spade terminals or ferrules, insert them to the bottom.

[Solid Wire]

When connecting two wires directly, use wires of the same size.



ø16

ø22

ø30

Miniature

Pilot Lights

LW-F

LB

LBW

Ordering Terms and Conditions

Thank you for using IDEC Products.

By purchasing products listed in our catalogs, datasheets, and the like (hereinafter referred to as "Catalogs") you agree to be bound by these terms and conditions. Please read and agree to the terms and conditions before placing your order.

1. Notes on contents of Catalogs

- (1) Rated values, performance values, and specification values of IDEC products listed in this Catalog are values acquired under respective conditions in independent testing, and do not guarantee values gained in combined
 - Also, durability varies depending on the usage environment and usage
- (2) Reference data and reference values listed in Catalogs are for reference purposes only, and do not guarantee that the product will always operate appropriately in that range.
- (3) The specifications / appearance and accessories of IDEC products listed in Catalogs are subject to change or termination of sales without notice, for improvement or other reasons.
- (4) The content of Catalogs is subject to change without notice.

2. Note on applications

- (1) If using IDEC products in combination with other products, confirm the applicable laws / regulations and standards.
 - Also, confirm that IDEC products are compatible with your systems, machines, devices, and the like by using under the actual conditions. IDEC shall bear no liability whatsoever regarding the compatibility with IDEC products.
- (2) The usage examples and application examples listed in Catalogs are for reference purposes only. Therefore, when introducing a product, confirm the performance and safety of the instruments, devices, and the like before use. Furthermore, regarding these examples, IDEC does not grant license to use IDEC products to you, and IDEC offers no warranties regarding the ownership of intellectual property rights or non-infringement upon the intellectual property rights of third parties.
- (3) When using IDEC products, be cautious when implementing the following.
 - Use of IDEC products with sufficient allowance for rating and performance
 - Safety design, including redundant design and malfunction prevention design that prevents other danger and damage even in the event that an IDEC product fails
 - Wiring and installation that ensures the IDEC product used in your system, machine, device, or the like can perform and function according to its specifications
- (4) Continuing to use an IDEC product even after the performance has deteriorated can result in abnormal heat, smoke, fires, and the like due to insulation deterioration or the like. Perform periodic maintenance for IDEC products and the systems, machines, devices, and the like in which they are used.
- (5) IDEC products are developed and manufactured as general-purpose products for general industrial products. They are not intended for use in the following applications, and in the event that you use an IDEC product for these applications, unless otherwise agreed upon between you and IDEC, IDEC shall provide no guarantees whatsoever regarding IDEC products.
 - Use in applications that require a high degree of safety, including nuclear power control equipment, transportation equipment (railroads / airplanes / ships / vehicles / vehicle instruments, etc.), equipment for use in outer space, elevating equipment, medical instruments, safety devices, or any other equipment, instruments, or the like that could endanger life or human health
 - ii. Use in applications that require a high degree of reliability, such as provision systems for gas / waterworks / electricity, etc., systems that operate continuously for 24 hours, and settlement systems
 - Use in applications where the product may be handled or used deviating from the specifications or conditions / environment listed in the Catalogs. such as equipment used outdoors or applications in environments subject to chemical pollution or electromagnetic interference If you would like to use IDEC products in the above applications, be sure to consult with an IDEC sales representative.

3. Inspections

We ask that you implement inspections for IDEC products you purchase without delay, as well as thoroughly keep in mind management/maintenance regarding handling of the product before and during the inspection.

4. Warranty

(1) Warranty period

The warranty period for IDEC products shall be one (1) year after purchase or delivery to the specified location. However, this shall not apply in cases where there is a different specification in the Catalogs or there is another agreement in place between you and IDEC.

(2) Warranty scope

Should a failure occur in an IDEC product during the above warranty period for reasons attributable to IDEC, then IDEC shall replace or repair that product, free of charge, at the purchase location / delivery location of the product, or an IDEC service base. However, failures caused by the following reasons shall be deemed outside the scope of this warranty.

- The product was handled or used deviating from the conditions / environment listed in the Catalogs
- The failure was caused by reasons other than an IDEC product
- Modification or repair was performed by a party other than IDEC
- The failure was caused by a software program of a party other than iv **IDEC**
- v. The product was used outside of its original purpose
- Replacement of maintenance parts, installation of accessories, or the like was not performed properly in accordance with the user's manual and
- vii. The failure could not have been predicted with the scientific and technical standards at the time when the product was shipped from
- viii. The failure was due to other causes not attributable to IDEC (including cases of force majeure such as natural disasters and other disasters) Furthermore, the warranty described here refers to a warranty on the IDEC product as a unit, and damages induced by the failure of an IDEC product are excluded from this warranty.

5. Limitation of liability

The warranty listed in this Agreement is the full and complete warranty for IDEC products, and IDEC shall bear no liability whatsoever regarding special damages, indirect damages, incidental damages, or passive damages that occurred due to an IDEC product.

6. Service scope

The prices of IDEC products do not include the cost of services, such as dispatching technicians. Therefore, separate fees are required in the following cases.

- (1) Instructions for installation / adjustment and accompaniment at test operation (including creating application software and testing operation, etc.)
- (2) Maintenance inspections, adjustments, and repairs
- (3) Technical instructions and technical training
- (4) Product tests or inspections specified by you

The above content assumes transactions and usage within your region. Please consult with an IDEC sales representative regarding transactions and usage outside of your region. Also, IDEC provides no guarantees whatsoever regarding IDEC products sold outside your region.

DEC CORPORATION

6-64, Nishi-Miyahara-2-Chome, Yodogawa-ku, Osaka 532-0004, Japan

USA	IDEC Corporation	Tel: +1-408-747-0550	opencontact@idec.com
Germany	APEM GmbH	Tel: +49-40-25 30 54-0	service@eu.idec.com
Singapore	IDEC Izumi Asia Pte. Ltd.	Tel: +65-6746-1155	info@sg.idec.com
Thailand	IDEC Asia (Thailand) Co., Ltd	Tel: +66-2-392-9765	sales@th.idec.com
India	IDEC Controls India Private Limited	Tel: +91-80679-35328	info_india@idec.com
Taiwan	IDEC Taiwan Corporation	Tel: +886-2-2577-6938	service@tw.idec.com

Hong Kong China Beiiing Branch

Japan

IDEC Izumi (H.K.) Co., Ltd. IDEC (Shanghai) Corporation Guangzhou Branch **IDEC Corporation**

Tel: +852-2803-8989 Tel: +86-21-6135-1515

Tel: +86-10-6581-6131

Tel: +86-20-8362-2394

Tel: +81-6-6398-2527

□ www.idec.com

info@hk.idec.com idec@cn idec com idec@cn.idec.com idec@cn.idec.com jp_marketing@idec.com

