# ø22 Switches & Pilot Lights

# TW Series



General-purpose switches & pilot lights for various applications. Heavy-duty type for high-level protection against harsh environment.



DC-DC converter types are not approved by standards.
See website for details on approvals and standards.









# **TW Series Selection Guide**

	·					
Function	Pushbutton					
Catagoni	Flush	Extended	Extended w/Full Shroud	ø29mm Mushroom	ø40mm Mushroom	
Category	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	
Shape						
Model	ABW1 AOW1	ABW2 AOW2	ABFW2 AOFW2	ABW3 AOW3	ABW4 AOW4	
Page	B-238	B-238	B-238	B-238	B-239	

Function		Pushbutton					
Category	ø40mm Mushroom w/Full Shroud	ø29mm Mushroom Pushlock Turn Reset	ø40mm Mushroom Pushlock Turn Reset	ø40mm Mushroom Push Turn Lock	ø29mm Mushroom		
	Momentary	FUSHIOCK TUTTI NESEL	FUSHIOCK TUTT NESEL		Pushlock Key Reset		
Shape							
Model	ABGW4	AVW3	AVW4	AJW4	AXW3		
Page	B-239	B-239	B-239	B-239	B-239		

Function	Pushbutton					
Category	ø40mm Mushroom	ø40mm Mushroom ø40mm Mushroom		Square Extended		
Calegoly	Pushlock Key Reset	Push Pull	Momentary/Maintained	Momentary/Maintained		
Shape						
Model	AXW4	AYW4	ABQW1 AOQW1	ABQW2 AOQW2		
Page	B-240	B-240	B-240	B-240		

Function	Pilot Light				
Category	Flush (Non-marking/Marking)	Square Flush (Marking)			
Shape		6			
Model	APW1 APW1B	APW2	APQW1B		
Page	B-241	B-241	B-241		

S
2
<b>_</b>
ല
_
Ð
$\infty$
<u> </u>
5
_
<u> </u>
Б
3

APEM
Switches & Pilot Lights
Control Boxes

Emergency Stop Switches Enabling Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers Operator Interfaces

Interfaces Sensors

AUTO-ID

Flush Silhouette Ø16 Ø22 Ø30 Miniature Pilot Lights

HW	
TW	
YW	

# **TW Series Selection Guide**

APEM Switches & Pilot Lights Control Boxes Emergency Stop Switches Enabling Switches Safety Products Explosion Proof Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator Interfaces Sensors AUTO-ID

Flush Silhouette
ø16
ø22
ø30
Miniature
Pilot Lights
HW
тw

YW

\_\_\_\_

Function	Illuminated Pushbutton					
Category	Extended (Non-marking/Marking)	Extended w/Full Shroud Square Extended (Non-marking/Marking) (Marking)		ø29mm Mushroom Pushlock Turn Reset	ø40mm Mushroom Pushlock Turn Reset	
	Momentary/Maintained	Momentary/Maintained	Momentary/Maintained	(Non-marking/Marking)	(Non-marking/Marking)	
Shape						
Part No.	ALW2, ALW2B, AOLW2, AOLW2B	ALFW2, AOLFW2 AlfW2B, AolfW2B	ALQW2B AOLQW2B	AVLW3 AVLW3B	AVLW4 AVLW4B	
Page	B-243	B-244	B-245	B-246	B-246	

Function		Illuminated Selector Switch		
Category	Knob	Lever	Кеу	Knob
Shape				
Part No.	ASW	ASW□L	ASW□K	ASLW
Page	B-249	B-250	B-251	B-252

# For more information, visit http://asia.idec.com

# Ø22 TW Series Switches & Pilot Lights

General-purpose switches & pilot lights for various applications. Heavy-duty type for high-level protection against harsh environment.

• Easy wiring for crimping terminal.

• UL, CSA, TÜV, CCC compliant.



# **Specifications and Ratings**

# **Contact Ratings**

Pus	Pushbuttons	Rated insulation voltage	600V	
Illun	ninated Pushbuttons	Rated continuous current	10A	
	ector Switches ninated Selector Switches	Contact ratings by utilization category IEC60947-5-1	AC-15 (A600) DC-13	

# **Contact Ratings by Utilization Category**

# HW-U10 (NO contact), HW-U01 (NC contact)

Operating Voltage		24V	48V	50V	110V	220V	440V	1	
Operating Current DC	AC-12 Control of resistive loads and solid state loads	10A	—	10A	10A	6A	2A	] .	
	50/60 Hz	AC-15 Control of electromagnetic loads (> 72 VA)	10A	_	7A	5A	3A	1A	1
	DC	DC-12 Control of resistive loads and solid state loads	10A	5A	_	2.2A	1.1A	_	1
	00	DC-13 Control of electromagnets	5A	2A	_	1.1A	0.6A	—	

# HW-U10R (EM contact/NO contact), HW-U01R (LB contact/NC contact)


Operating Voltage				48V	50V	110V	220V	440V	] _"
	AC	AC-12 Control of resistive loads and solid state loads	5A	_	5A	5A	3A	1A	] F
Operating	Current	AC-15 Control of electromagnetic loads (> 72 VA)	5A	—	3.5A	2.5A	1.5A	0.5A	] -
Current		DC-12 Control of resistive loads and solid state loads	5A	2.5A	—	1.1A	0.55A	—	]
DC		DC-13 Control of electromagnets	2.5A	1A	—	0.55A	0.3A	—	] _

• The operating current represents the classification by making and breaking currents (IEC 60947-5-1).

· Contact materials: Silver contacts

• Minimum applicable load: 3V AC/DC, 5 mA (applicable range may vary with operating conditions and load types)

# **HW-U Contact Block**



Part No.	HW-U10	HW-U01	HW-U10R	HW-U01R			
Contact		~_		~			
Contact	1N0	1NC	EM (NO) (early make)	LB (NC) (late break)			
Contact No.	3-4	1-2	3-4	1-2			
Housing	Blue	Purple red	Blue	Purple red			
Push Rod	Green	Red	Black	White			
Weight	Approx. 11g						

• Up to 2 layers (4 blocks) can be attached. AYW: 2 blocks (1 layer) maximum.

• Gold contacts available (gold-plated silver)

# APEM

Pilot Lights Control Boxes

Emergency Stop Switches

Enabling

Switches Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Circuit Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces

Sensors

AUTO-ID

Flush Silhouette
ø16
ø22
ø30

Miniature Pilot Lights

HW

TW YW

• doid contacts available (gold-plated silver)

# ø22 TW Series Switches & Pilot Lights

# **LED Specifications**

Pilot	llmið		LED lamp						
et i	Unit	Color	Rated Voltage		Operating Voltage		Lamp Base	Part No.	
Lights			6V AC/DC		6V AC/DC			LSTD-6*	
nts			12V AC/DC		12V AC/DC			LSTD-1*	
			24V AC/DC		24V AC/DC			LSTD-2*	
			R (red)		100/110V AC		100/110V AC		
APEM	Pilot light	ilot light G (green) 11			115/120V AC	±10%	BA9S/13		
Switches &	Illuminated pushbutton	uminated pushbutton Y (yellow) 200/220V AC		200/220V AC					
Pilot Lights	Illuminated selector switch		230/240V AC	50/60 Hz	230/240V AC			LSTD-6*	
Control Boxes		PW (pure white)	380V AC		380V AC			L31D-0*	
Emergency			400/440V AC		400/440V AC				
Stop Switches		48			480V AC				
Enabling Switches			110V DC		90 to 140V DC				

· See below for details on LED lamp ratings.

Safety Products • Color codes for units without LED lamps:

R (red), G (green), A (amber), Y (yellow), S (blue) Explosion Proof

When using a commercially available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape. Terminal Blocks Make sure of correct operation before installation. The operation of TW series cannot be guaranteed when a commercially available lamp is used.

## Relays & Sockets **Power Unit Terminal** Circuit

Protectors			Illuminated Unit							
Power Supplies	Power Unit	Full voltage adapter	Transf	ormer	DC-DC converter	Full voltage adapter (integrated)				
LED Illumination	Dated Valtage				110/ 00					
Controllers	Rated Voltage	6, 12, 24V AC/DC	100 to 240V AC	380V AC minimum	110V DC	6, 12, 24V AC/DC				
Operator Interfaces	Polarity	None	None	None	X1 (+) X2 (–)	None				
Sensors		X1		-						
AUTO-ID		6 B	THE OWNER			X1				
	Shape/Terminal	S.C.C.	- E		X1	X2				
Flush Silhouette			X1 X2		X2					
ø16										

# **LED Lamp Ratings**

ø30 LSTD

Miniature	Part No.			LSTD-6*		LST	LSTD-1*		STD-2*			
Dilat Lishta	Lamp Base		BA9S/13	A9S/13								
Pilot Lights	Rated Voltag	ge	6V AC/DC			12V AC/DC		24V AC/DC				
	Voltage Ran	ge	6V AC/DC ±10	)%		12V AC/DC ±10%		24V AC/DC ±10%				
		Color	R, A	G, PW	S	R, G, A, PW	S	R, G, A, PW	S			
HW	Current Draw	DC	7mA	5.5mA	4.5mA	10mA	8mA	10mA	8mA			
HW	Diaw	AC	8mA	8mA	7mA	11mA	9mA	11mA	9mA			
тw	Lamp Base	Color	Same as illum	ination color (F	PW: gray)							
YW	Voltage Mar	king	Die stamped on the base									
1 11	Life (reference value) Approx. 50,000 hours (The luminance is reduced to 50% the initia					l intensity when used o	on complete DC at 2	5°C.)				
	Internal Circuit						Example: LSTD-2P					
	Weight		Approx. 2g									

• Specify a color code in place of \*. R (red), G (green), A (amber), S (blue), PW (pure white)

• Use a pure white (PW) LED for yellow (Y) illumination.

# ø22 TW Series Switches & Pilot Lights

C	no	rifi	ഹ	tic	ons
J	pe	UIII	ua	uc	лıs

Specifications				<u></u>
Operating Temperature			-25 to +50°C (no freezing)	& Pilot Lights
Operating Humidity			45 to 85% RH (no condensation)	et t
Storage Temperature			-40 to +80°C (no freezing)	igh
Contact Resistance			50 mΩ maximum (initial value)	2
Insulation Resistance			100 MΩ minimum (500V DC megger)	
Dielectric Strength			Between live and dead metal parts: 2,500V AC, 1 minute (Full voltage and illuminated units: 2,000V AC, 1 minute)	APEM
Vibration Resistance	Operating extremes		5 to 55 Hz, amplitude 0.5 mm	Switches &
	Damage limits		30 Hz, amplitude 1.5 mm	Pilot Lights
Shock Resistance	Operating extremes		100m/s <sup>2</sup>	Control Boxes
Shock Resistance	Damage limits		1,000m/s <sup>2</sup> (*5)	Emergency Stop Switches
		Momentary	5,000,000	Enabling
	D. Haller	Maintained	500,000 (3 contact blocks and over: 250,000)	Switches
	Pushbutton	Push-to-lock, Turn-to-reset	500,000	Safety Products
		Other	500,000	Explosion Proof
Mechanical Life		Momentary	5,000,000	Terminal Blocks
(minimum operations)	Illuminated pushbutton	Maintained	500,000 (3 contact blocks and over: 250,000)	
		Push-to-lock, Turn-to-reset	500,000	Relays & Sockets
	Selector switch		500,000	Circuit Protectors
	Key selector switch		500,000	
	Illuminated selector switch		500,000	Power Supplies
		Momentary	500,000 (*1)	LED Illumination
	D. Haller	Maintained	500,000 (3 contact blocks and over: 250,000) (*3)	Controllers
	Pushbutton	Push-to-lock, Turn-to-reset	500,000 (*3)	Operator
		Other	500,000	Interfaces
Electrical Life (*4)		Momentary	500,000 (*1)	Sensors
(minimum operations)	Illuminated pushbutton	Maintained	500,000 (3 contact blocks and over: 250,000) (*3)	AUTO-ID
		Push-to-lock, Turn-to-reset	500,000 (*3)	
	Selector switch		500,000 (*2)	
	Key selector switch		500,000 (*2)	<b>—</b> ]
	Illuminated selector switch		250,000 (*2)	Flush Silhouette
			68g (ABW122) 33g (APW122D)	ø16
			89g (ALW22222D)	ø22
Weight (Apporox.)			68g (ASW222) 107g (ASW2K22) 90g (ASLW22222D)	ø30
			95g (APW126D)	Miniature

\*1) Switching frequency 1,800 operations/h, duty ratio 40%

\*2) Switching frequency 1,200 operations/h, duty ratio 40%

\*3) Switching frequency 900 operations/h, duty ratio 40%

\*4) Load condition 220V AC, 3A (AC-15)

\*5) Illuminated unit with four contact blocks with transformer and DC-DC converter types: 500 m/s<sup>2</sup>

# **Degree of Protection**

	IEC 60529	
A====	Pushbutton Pilot light Illuminated pushbutton with round lens Selector switch	IP65
(Part number that starts with "A")	Pushlock key reset pushbutton Illuminated selector switch Key selector switch	IP54

# For harsh environment such as torrid/frigid area

TW series for harsh environment such as torrid/frigid area is also available (not approved by standards). Contact IDEC for details.


Pilot Lights

HW

YW

# Mounting Hole Layout

# Panel Cut (IEC60947-5-1)



- The minimum mounting centers are applicable to switches with one layer of contact blocks (one to two contact blocks). When two layers of contact blocks are mounted, determine the minimum mounting centers in consideration of convenience for wiring.
- 1\*) ø40 mm mushroom button type: 40 mm minimum
- 1\*) 2-position, 3-position lever selector switch: 39 mm minimum
- 1\*) 4-position, 5-position lever selector switch: 50 mm minimum
- When high temperature is expected, take necessary measures such as securing sufficient mounting centers or using a cooling fan.

When using a commercially available lamp, choose a lamp with rated voltage

Make sure of correct operation before installation. The operation of TW series

5 to 30V AC/DC and 1W maximum, and with the same base and shape.

cannot be guaranteed when a commercially available lamp is used.

• The ☆3.2 <sup>+0.2</sup>/<sub>0</sub> mm recess is for preventing rotation and is not necessary when the nameplate or anti-rotation ring is not used.

· Color codes for units without LED lamps:

R (red), G (green), A (amber), Y (yellow), S (blue)


# Ordering Information

# Standard models

- Specify Ordering No. when ordering.
- Specify a button or lens color code in place of \*.
- An LED lamp is installed in pilot lights, illuminated pushbuttons, and illuminated selector switches unless otherwise specified.
- Pilot light of full voltage adapter type is equipped with a terminal cover.
- Nameplates and accessories are ordered separately. See B-256 to B-259.

# Pushbuttons (B-238 to B-240)

When specifying gold-plated silver contact and contact configuration:



APW 2 <u>126</u> DR

Operating voltage 99: Without LED lamp 66: 6V AC/DC 11: 12V AC/DC 22: 24V AC/DC 16: 100/110V AC 126: 115/120V AC 26: 200/220V AC 246: 230/240V AC 386: 380V AC 46: 400/440V AC 486: 480V AC

• See B-237 for how to specify 110V DC type (DC-DC converter).

Note: Color codes for units without LED lamps: R (red), G (green), A (amber), Y (yellow), S (blue) When using a commercially available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape. Make sure of correct operation before installation. The operation of TW series cannot be guaranteed when a commercially available lamp is used.

APEM

Control Boxes

Emergency Stop Switches

Enabling

Switches

Safety Products Explosion Proof

Terminal Blocks Relays & Sockets

Circuit

Protectors

Power Supplies

LED Illumination

Controllers

Operator Interfaces Sensors

AUTO-ID

# For more information, visit http://asia.idec.com

# **Ordering Information**

# Illuminated Pushbuttons (B-243 to B-246)

When specifying gold-plated silver contact, contact configuration, and LED operating voltage:

ALFW	2	26	13	DR -	MAU
------	---	----	----	------	-----

ALFW 2 20	<u>5 13</u> DR - <u>MAU</u>				
Т		— Optional contact	MAU	Gold contact	
		<ul> <li>Contact configuration</li> </ul>	10:	1N0	
		-	01:	1NC	
			11:	1N01NC	
			20:	2N0	
			02:	2NC	
			21:	2NO1NC	
			21. 12:	1NO2NC	
			30:	3N0	
			03:	3NC	
			31:	3N01NC	
			22:	2NO2NC	
			13:	1NO3NC	
			40:	4N0	
			04:	4NC	
L		— Operating voltage	99:	Without LED lamp	
		oporating rolago	66:	6V AC/DC	
			11:	12V AC/DC	
				24V AC/DC	
			16:	100/110V AC	
				200/220V AC	
			246:		
			386:		
			46:	400/440V AC	
			486:	480V AC	

Note:

• Illuminated pushbuttons of 24V AC/DC and below with 2 or 4 contact blocks have a dummy block.

• Illuminated pushbuttons of 100V AC and over is not available with 1 or 3 contact blocks.

• See B-237 for how to specify 110V DC type (DC-DC converter).

• Color codes for units without LED lamps:

R (red), G (green), A (amber), Y (yellow), S (blue)

When using a commercially available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape. Make sure of correct operation before installation. The operation of TW series cannot be guaranteed when a commercially available lamp is used.

# Selector Switches (B-249 to B-251)

When specifying gold-plated silver contact, key removal position, and key number:

ASW	2	11 -	MAU	

IAU	
	Optional contact
	•
	———Contact arrangement codes

MAU: Gold-plated silver See B-253 to B-255.

How to specify key removal/retained position

	Position	Removable Position	Code	Part No. Example
		Removable in all positions	—	ASW2K20
2-position	Maintained	Removable in left only	В	ASW2K20B
		Removable in right only	C	ASW2K20C
	Spring return from right	Removable in left only	—	ASW21K20
	Spring return from left	Removable in right only	—	ASW22K20
		Removable in all positions	—	ASW3K20
		Removable in left and center only	В	ASW3K20B
		Removable in right and center only	C	ASW3K20C
	Maintained	Removable in center only	D	ASW3K20D
		Removable in right and left only	E	ASW3K20E
		Removable in left only	G	ASW3K20G
3-position		Removable in right only	Н	ASW3K20H
5-p0510011		Removable in left and center only	—	ASW31K20
	Spring return from right	Removable in center only	D	ASW31K20D
		Removable in left only	G	ASW31K20G
		Removable in right and center only	—	ASW32K20
	Spring return from left	Removable in center only	D	ASW32K20D
		Removable in right only	Н	ASW32K20H
	Spring return two-way	Removable in center only	—	ASW33K20

• The key cannot be removed in a spring returned position.



APEM

Control Boxes Emergency Stop Switches Enabling Switches Safety Products Explosion Proof Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies LED Illumination Controllers Operator

ø16 ø22 ø30

Flush Silhouette

Interfaces

Sensors

AUTO-ID

Miniature


Pilot Lights

HW

YW

İ	Illuminated selector switches (B-252)
ilot Lights	When specifying gold-plated silver contact, contact configuration, and LED operating voltage:
nts	ASLW 2 <u>136</u> <u>22</u> DR - <u>MAU</u>
	Optional contact MAU Gold contact Contact arrangement codes See B-253 to B-255.
APEM	
Switches &	Operating Voltage 99: Without LED lamp 66: 6V AC/DC
Pilot Lights	11: 12V AC/DC
Control Boxes	22: 24V AC/DC 16: 100/110V AC
Emergency Stop Switches	136: 115/120V AC
Enabling Switches	26: 200/220V AC 256: 230/240V AC
Safety Products	386: 380V AC
	46: 400/440V AC 486: 480V AC
Explosion Proof	Note:
Terminal Blocks	• Illuminated selector switches of 24V AC/DC and below with 2 or 4 contact blocks have a dummy block.
Relays & Sockets	<ul> <li>Illuminated selector switches of 100V AC and over is not available with 1 or 3 contact blocks.</li> <li>See below for how to specify 110V DC type (DC-DC converter).</li> </ul>
Circuit Protectors	Color codes for units without LED lamps:
Power Supplies	R (red), G (green), A (amber), Y (yellow), S (blue) When using a commercially available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape.
LED Illumination	Make sure of correct operation before installation. The operation of TW series cannot be guaranteed when a commercially available lamp is used.
Controllers	DC-DC Converter (110V DC)
Operator Interfaces	When specifying illuminated pushbuttons, illuminated selector switches, and pilot lights:
Sensors	ALW 2 <u>16</u> 22 <u>p</u> DG
AUTO-ID	Operating Voltage 16
	ASLW 2 <u>16</u> 11 <u>p</u> DY
	Operating Voltage 16
Flush Silhouette	APW 1 <u>16</u> <u>D</u> DR
ø16	Operating Voltage 16
ø22	
ø30	Note: • DC-DC converter type (110V DC) is not approved by standards (90 to 140V DC).
Miniature	DC-DC converter type is not available with 1 or 3 contact blocks.
Pilot Lights	
HW	
TW	
YW	





• Specify a color code in place of \* in Part No.

B: black, G: green, R: red, Y: yellow, S: blue, W: white


· Round bezel: Mat aluminum color

# Bottom View (non-illuminated)

Dummy block



1NO contact block





• Pushbuttons: M3.5 Terminal screws

. For 1 NC contact, the contact block will mount on the opposite side.

• See B-267 for wiring.

See B-235 for other contact configurations and gold-plated silver contacts.

· Integrated terminal cover

2/4 contact blocks

Download catalogs and CAD from http://asia.idec.com/downloads

# ø22 TW Series Pushbuttons

# Mushroom / Pushlock Turn Reset / Push Turn Lock / Pushlock Key Reset

& Pilot Lights	Musin oom / Tusine					Package Quantity: 1
Ē	Shape	Operation	Contact	Part No.	Color Code	Dimensions (mm)
ghts	ø40mm Mushroom		1N0	ABW410*		
	ABW4 AOW4		1NC	ABW401*		
		Momentary	1NO-1NC	ABW411*	_	
APEM		Momentary	2N0	ABW420*	-	Adust ringPanel thickness 1 to 6
Switches & Pilot Lights			2NC	ABW402*	B G	
Control Boxes			2N0-2NC	ABW422*	R	
Emergency			1N0	A0W410*	Y S	
Stop Switches Enabling			1NC	A0W401*	Ŵ	49.4 (1-2 blocks) 13
Switches		Maintained	1NO-1NC	A0W411*		69.4 (3-4 blocks)
Safety Products		Mannanieu	2N0	A0W420*		
Explosion Proof			2NC	A0W402*		
Terminal Blocks			2N0-2NC	A0W422*		
	Ø40mm Mushroom w/Full Shroud		1N0	ABGW410*	_	Adust ring Panel thickness 1 to 6
Relays & Sockets	ABGW4		1NC	ABGW401*	B G	
Circuit Protectors		Momentary	1NO-1NC	ABGW411*	R	
Power Supplies		Momontary	2N0	ABGW420*	Y S	
LED Illumination			2NC	ABGW402*	Ŵ	49.4 (1-2 blocks) 69.4 (3-4 blocks) 23.
Controllers			2N0-2NC	ABGW422*		- U3.4 (3°4 LIUCKS)
Operator	ø29mm Mushroom Pushlock Turn F AVW3	1N0	AVW310*	-	Adust ringPanel thickness 1 to 6 Reset angle 75°	
Interfaces	AVWS		1NC	AVW301*		
Sensors			1N0-1NC	AVW311*	R	
AUTO-ID		2N0	AVW320*	Y		
		2NC	AVW302*		49.4 (1-2 blocks) 13 69.4 (3-4 blocks) 22.5	
			2N0-2NC	AVW322*		
Flush Silhouette	ø40mm Mushroom Pushlock Turn F AVW4	Reset (*1)	1N0	AVW410*	-	Adjust ring Adjust
			1NC	AVW401*	-	
ø16			1NO-1NC	AVW411*	R	
ø22			2N0	AVW420*	Y	
ø30			2NC	AVW402*	-	49.4 (1-2 blocks) 13 69.4 (3-4 blocks) 22.5
Miniature			2NO-2NC	AVW422*		<b>€ 1 1 1 1 1 1</b>
Pilot Lights	ø40mm Mushroom Push Turn Lock AJW4		1N0	AJW410*	-	Adjust ring
			1NC	AJW401*	В	
			1NO-1NC	AJW411*	G	
			2N0	AJW420*	R Y	
HW		2NC	AJW402*	-	49.4 (1-2 blocks) 13 69.4 (3-4 blocks) 22.5	
TW		1 /44	2NO-2NC	AJW422*		
YW	ø29mm Mushroom Pushlock Key R AXW3	eset (*1)	1N0	AXW310R	-	
			1NC	AXW301R	-	
			1NO-1NC	AXW311R	R	
			2N0	AXW320R	-	
			2NC	AXW302R	-	49.4 (1-2 blocks) 24.5 69.4 (3-4 blocks) 47 45°
			2N0-2NC	AXW322R		Reset (unlock)

• Specify a color code in place of \* in Part No. B (black), G (green), R (red),

- Y (yellow), S (blue), W (white)
- Round bezel (metal): Mat aluminum color
- Pushbuttons with one or three contact blocks contain a dummy block.
- See **B-235** for other contact configurations and gold-plated silver contacts.
- Pushbuttons: terminal screws M3.5, integrated terminal cover
- See B-238 for bottom view.
- \*1) AVW3, AVW4, and AXW3 pushbuttons cannot be used as emergency stop switches. When emergency stop switches are required, use XW series pushbuttons (ISO 13850 and IEC 60947-5-5 compliant).

# Pushbutton operation

# **Push Turn Lock**

Button is locked when turned clockwise in the depressed position and is reset when turned counterclockwise.

# ø22 TW Series Pushbuttons

Switches &

# Pushlock Key Reset / Push-Pull / Square Flush / Square Extended

					Package Quantity: 1	, Pilot Lights
Shape	Operation	Contact	Part No.	Color Code	Dimensions (mm)	tLi
ø40mm Mushroom Pushlock Key	/ Reset (*1)	1N0	AXW410R			ghts
AXW4		1NC	AXW401R	-	Adjust ring Panel thickness 1 to 6	
		1NO-1NC	AXW411R	-		
				R		APEM
	5	2N0	AXW420R	-	49.4 (1-2 blocks) 24.5 [29.6	Switches & Pilot Lights
9		2NC	AXW402R		69.4 (3-4 blocks) 47	Control Boxes
		2N0-2NC	AXW422R		Reset (unlock)	Emergency
ø40mm Mushroom Push-Pull		1N0	AYW410*		Adjust ring Panel thickness 1 to 6	Stop Switches
AYW4		1NC	AYW401*	В		Enabling Switches
				G R		Safety Products
		1NO-1NC	AYW411*	Y		Explosion Proof
		2N0	AYW420*	S W		
		2NC	AYW402*		49.4 (1-2 blocks) 25 30.5 29.6	Terminal Blocks
Square Flush ABQW1 AOQW1		1N0	ABQW110*			Relays & Sockets
		1NC	ABQW101*	_		Circuit Protectors
AUQWI	Momentary	1NO-1NC	ABQW111*	-	Adjust size Development day 0	Power Supplies
-		2N0	ABQW120*	В	Adjust ring Panel thickness 1 to 6	
1 Contraction		2NC 2N0-2NC	ABQW102*	G		LED Illumination
		2NU-2NC 1NO	ABQW122* A0QW110*	R Y	│ ╡╆·─·┝·─}─╫ <u>┟</u> ╫┼┢╡ │	Controllers
		1NC	AOQW110* AOQW101*	S		Operator
		1N0-1NC	A0QW101*	W	49.4 (1-2 blocks) 69.4 (3-4 blocks) 13.1	Interfaces
	Maintained	2N0	A0QW120*	-		Sensors
		2NC	A0QW102*			AUTO-ID
		2N0-2NC	A0QW122*			
Square Extended		1N0	ABQW210*			
ABQW2		1NC	ABQW201*	]		
A0QW2	Momentary	1NO-1NC	ABQW211*	]		Flush Silhouette
-	womentaly	2N0	ABQW220*	B	Adjust ring Panel thickness 1 to 6	
		2NC	ABQW202*	G		ø16
		2N0-2NC	ABQW222*	R		ø22
		1N0	A0QW210*	Y S		-00
		1NC	A0QW201*	- W		ø30
	Maintained	1NO-1NC	A0QW211*	-	49.4 (1-2 blocks) 13.1 69.4 (3-4 blocks) 19.4 29.6	Miniature
		2N0	A0QW220*	-		Pilot Lights
		2NC	A0QW202*	-		
		2N0-2NC	A0QW222*			

• Specify a color code in place of  $\ast$  in Part No. B (black), G (green), R (red), Y (yellow), S (blue), W (white)

- Round bezel (metal): Mat aluminum color
- Square bezel (plastic): Black
- Pushbuttons with one or three contact blocks contain a dummy block.
- See **B-235** for other contact configurations and gold-plated silver contacts.
- Push-pull switch can have a maximum of two contact blocks.
- Pushbuttons: terminal screws M3.5, integrated terminal cover
- See **B-238** for bottom view.
- \*1) AXW4 pushbuttons with red operator cannot be used as emergency stop switches. When emergency stop switches are required, use XW series pushbuttons (ISO 13850 and IEC 60947-5-5 compliant).

# Pushbutton operation

# Push-Pull

2-position switches with button maintained in both depressed and reset positions.

# **Push-Pull contact operation**

Contact		AYW4					
CONTACT	Pu	ısh	Pull				
1N0	σ	م	<u> </u>				
1NC	•	•					
1N0-1NC	0'0	<u>o'o</u> ●1●		●⊥●			
2N0	0'0	0'0	40	o_ o			
2NC	●⊥●	●⊥●		●⊥●			

HW	
TW	
YW	


# ø22 TW Series Pilot Lights

hes & Pilot Lights	Round Flush / Dome / Square Fl	ush Pilot Lights	S		
Pilo					Package Quantity: 1
tLig	Shape	Illumination	Rated Voltage	Part No.	Color Code
APEM	Round Flush APW1		24V AC/DC	APW122D*	
Switches &					R G
Pilot Lights Control Boxes	(24V AC/DC)	LED	100/110V AC	APW116D*	Y A
Emergency Stop Switches Enabling Switches			200/220V AC	APW126D*	_ S _ PW
Safety Products	With transformer (100/110V AC)		200/2200 40	AT WIZOD*	
Explosion Proof	Round Flush (Marking)				
Terminal Blocks Relays & Sockets	APW1B		24V AC/DC	APW1B22D*	
Circuit					R
Protectors Power Supplies	(24V AC/DC)	LED	100/110V AC	APW1B16D*	G Y
LED Illumination					A S
Controllers					– PW
Operator Interfaces			200/220V AC	APW1B26D*	
Sensors	With transformer (100/110V AC)				
AUTO-ID	Dome APW2		24V AC/DC	APW222D*	- R
Flush Silhouette	(24V AC/DC)				G
ø16		LED	100/110V AC	APW216D*	Y A S
ø22 ø30			200/220V AC	APW226D*	– PW
Miniature	With transformer (100/110V AC)				
Pilot Lights	Square Flush (Marking) APQW1B		24V AC/DC	APQW1B22D*	
HW					R
TW	(24V AC/DC)	LED	100/110V AC	APQW1B16D*	G Y A
YW					S PW
			200/220V AC	APQW1B26D*	
	With transformer (100/110V AC)				

• Specify a color code in place of \* in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)

- An LED lamp is installed in pilot lights unless otherwise specified.
- The PW (pure white) lens of marking type consists of a clear lens and a white marking plate.
- See **B-265** for marking plate size and engraving area.
- Round bezel (metal): Mat aluminum color
- Square bezel (plastic): Black
- See **B-235** for other contact configurations.
- See B-235 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- See B-235 for how to specify units without LED lamps. When using a commercially available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape. The operation of pilot lights cannot be guaranteed when a commercially available lamp is used.

For more information, visit http://asia.idec.com



With terminal cover (APS-PVL)

• See B-268 for wiring.

Integrated terminal cover

For DC-DC Converter types, terminal X1 is  $\oplus$ , X2 is  $\ominus$ . Integrated terminal cover

HW YW

# ø22 TW Series Illuminated Pushbuttons

# Switches & Pilot Lights

<u> </u>	LED Roun	a Extende <u>a /</u>	Round Extend	ed (Marking I	(ype)		
Pilo							Package Quantit
s & Pilot Lights	Shape	Illumination	Operation	Rated Voltage	Contact Configuration	Part No.	Color Code
ts.	Round Extended				1NO-1NC	ALW22211D*	
	ALW2			24V AC/DC	2N0	ALW22220D*	
	AOLW2				2N0-2NC	ALW22222D*	R
APEM					1NO-1NC	ALW21611D*	G
Switches &	1		Momentary	100/110V AC	2N0	ALW21620D*	Y A
Pilot Lights					2N0-2NC	ALW21622D*	A S
Control Boxes					1NO-1NC	ALW22611D*	PW
Emergency				200/220V AC	2N0	ALW22620D*	
Stop Switches	(24V AC/DC)				2NO-2NC	ALW22622D*	
Enabling Switches		LED –			1NO-1NC	A0LW22211D*	
afety Products				24V AC/DC	2N0	A0LW22220D*	
					2NO-2NC	A0LW22222D*	R
plosion Proof					1NO-1NC	A0LW21611D*	G
rminal Blocks			Maintained	100/110V AC	2N0	A0LW21620D*	Y A S PW
IIIIIIai Diucks					2N0-2NC	A0LW21622D*	
ays & Sockets				200/220V AC	1NO-1NC	A0LW22611D*	
Circuit	With transformer				2N0	A0LW22620D*	
Protectors	(100/110V AC)				2NO-2NC	A0LW22622D*	
ower Supplies	Round Extended (Marking)			24V AC/DC	1NO-1NC	ALW2B2211D*	R G Y A S
) Illumination	ALW2B				2N0	ALW2B2220D*	
Jilluminauon	AOLW2B				2NO-2NC	ALW2B2222D*	
Controllers				100/110V AC	1NO-1NC	ALW2B1611D*	
Operator	1 million		Momentary		2N0	ALW2B1620D*	
Interfaces			· · · · · · · · · · · · · · · · · · ·		2NO-2NC	ALW2B1622D*	
Sensors					1NO-1NC	ALW2B2611D*	PW
				200/220V AC	2N0	ALW2B2620D*	
AUTO-ID	(24V AC/DC)				2NO-2NC	ALW2B2622D*	
		LED –			1NO-1NC	AOLW2B2211D*	
				24V AC/DC	2N0	AOLW2B2220D*	
ah Cilhautta					2NO-2NC	AOLW2B2222D*	
ish Silhouette					1NO-1NC	AOLW2B1611D*	G
ø16			Maintained	100/110V AC	2N0	AOLW2B1620D*	
-00-					2NO-2NC	AOLW2B1622D*	— A S
ø22					1NO-1NC	AOLW2B2611D*	PW
ø30	With transformer			200/220V AC	2N0	AOLW2B2620D*	
	(100/110V AC)				2N0-2NC	AOLW2B2622D*	

• Specify a color code in place of \* in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white) Pilot Lights

• The PW (pure white) lens of marking type consists of a clear lens and a white marking plate.

• See B-265 for marking plate size and engraving area.

• An LED lamp is installed in illuminated pushbuttons unless otherwise specified.

• Round bezel (metal): Mat aluminum color

- See B-236 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.
- See B-236 for other contact configurations and gold-plated silver contacts.
- Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.

YW • See B-236 for how to specify units without LED lamps. When using a commercially available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape. The operation of pilot lights cannot be guaranteed when a commercially available lamp is used.

HW

ALFW21620D\*

ALFW21622D\*

ALFW22611D\*

ALFW22620D\*

ALFW22622D\*

A0LFW22211D\*

AOLFW22220D\*

AOLFW22222D\*

A0LFW21611D\*

AOLFW21620D\*

AOLFW21622D\*

A0LFW22611D\*

AOLFW22620D\*

A0LFW22622D\* ALFW2B2211D\*

ALFW2B2220D\*

ALFW2B2222D\*

ALFW2B1611D\*

ALFW2B1620D\*

ALFW2B1622D\*

ALFW2B2611D\*

ALFW2B2620D\*

ALFW2B2622D\*

AOLFW2B2211D\*

AOLFW2B2220D\*

AOLFW2B2222D\*

AOLFW2B1611D\*

AOLFW2B1620D\*

AOLFW2B1622D\*

AOLFW2B2611D\*

AOLFW2B2620D\*

AOLFW2B2622D\*

R G Y

А

S

PW

R

G

Y

А

S

PW

R

G

Ŷ

А

S

PW

R G Y

A S

PW

LED	Round	Round Extended with Full Shroud / Round Extended with Full Shroud (Marking 1							
							Package Quantity: 1		
Shape		Illumination	Operation	Rated Voltage	Contact Configuration	Part No.	Color Code		
Round Extended with	Full Shroud				1NO-1NC	ALFW22211D*			
ALFW2				24V AC/DC	2N0	ALFW22220D*			
A0LFW2					2N0-2NC	ALFW22222D*	R		
					1NO-1NC	ALFW21611D*	G		

Momentary

Maintained

Momentary

Maintained

100/110V AC

200/220V AC

24V AC/DC

100/110V AC

200/220V AC

24V AC/DC

100/110V AC

200/220V AC

24V AC/DC

100/110V AC

200/220V AC

2N0

2NO-2NC

1NO-1NC

2N0

2NO-2NC

1NO-1NC

2N0

2NO-2NC

1NO-1NC

2N0

2NO-2NC

1NO-1NC

2N0

2N0-2NC

1NO-1NC

2N0

2N0-2NC

1NO-1NC

2N0

2NO-2NC

1NO-1NC

2N0

2NO-2NC

1NO-1NC

2N0 2NO-2NC

1NO-1NC

2N0

2NO-2NC

1NO-1NC

2N0

2NO-2NC

APEM
Switches & Pilot Lights
Control Boxes
Emergency Stop Switches
Enabling Switches
Safety Products
Explosion Proof
Terminal Blocks
Relays & Sockets
Circuit Protectors
Power Supplies
LED Illumination
Controllers
Operator Interfaces
Sensors
AUTO-ID
Flush Silhouette
ø16
ø22
ø30

Miniature

Pilot Lights

HW

YW

• Specify a color code in place of \* in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)

• The PW (pure white) lens of marking type consists of a clear lens and a white marking plate.

LED

LED

See B-265 for marking plate size and engraving area.

• An LED lamp is installed in illuminated pushbuttons unless otherwise specified.

• Round bezel (metal): Mat aluminum color

(24V AC/DC)

With transformer

(100/110V AC)

Round Extended with Full Shroud

4V AC/DC

With transformer

(100/110V AC)

(Marking Type)

ALFW2B

AOLFW2B

• See B-236 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.

• See B-236 for other contact configurations and gold-plated silver contacts.

• Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.

• See B-236 for how to specify units without LED lamps. When using a commercially available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape. The operation of pilot lights cannot be guaranteed when a commercially available lamp is used.

Download catalogs and CAD from http://asia.idec.com/downloads

Controllers

Operator

Sensors

AUTO-ID

LED

# Square Extended (Marking Type)

Pilo	Package Quantity: 1									
Pilot Lights	Shape	Illumination	Operation	Rated Voltage	Contact Configuration	Part No.	Color Code			
ts.	Square Extended (Marking Type)				1NO-1NC	ALQW2B2211D*				
	ALQW2B AOLQW2B			24V AC/DC	2N0	ALQW2B2220D*				
APEM	AULQWZD				2N0-2NC	ALQW2B2222D*	R			
	(24V AC/DC)				1NO-1NC	ALQW2B1611D*	G			
Switches & Pilot Lights			Momentary	100/110V AC	2N0	ALQW2B1620D*	Y A			
Control Boxes					2N0-2NC	ALQW2B1622D*	S			
Emergency					1NO-1NC	ALQW2B2611D*	PW			
Stop Switches				200/220V AC	2N0	ALQW2B2620D*	_			
Enabling Switches					2N0-2NC	ALQW2B2622D*				
Safety Products		LED -			1NO-1NC	AOLQW2B2211D*				
				24V AC/DC	2N0	AOLQW2B2220D*				
Explosion Proof					2N0-2NC	AOLQW2B2222D*	R			
Terminal Blocks					1NO-1NC	AOLQW2B1611D*	G			
Relays & Sockets			Maintained	100/110V AC	2N0	AOLQW2B1620D*	Y A			
Circuit					2N0-2NC	AOLQW2B1622D*	Ś			
Protectors					1NO-1NC	AOLQW2B2611D*	PW			
Power Supplies	With transformer			200/220V AC	2N0	AOLQW2B2620D*	1			
LED Illumination	(100/110V AC)				2NO-2NC	AOLQW2B2622D*				

• Specify a color code in place of \* in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)

• The PW (pure white) lens of marking type consists of a clear lens and a white marking plate.

• See B-265 for marking plate size and engraving area. Interfaces

• An LED lamp is installed in illuminated pushbuttons unless otherwise specified.

Square bezel (plastic): Black

• See B-236 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.

• See B-236 for other contact configurations and gold-plated silver contacts.

• Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.

• See B-236 for how to specify units without LED lamps. When using a commercially available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape. The operation of pilot lights cannot be guaranteed when a commercially available lamp is used.

-	Flush Silhouette
-	ø16
	ø30
_	Miniature
	Pilot Lights
_	
_	HW
	YW

# ø22 TW Series Illuminated Pushbuttons

# Switches & Pilot Lig

Package Quantity: 1

Part NO.	COIOI COUE	gh
/32211D*		ts.
/32220D*		
/32222D*		APEM
/31611D*		Switches &
/31620D*	R	Pilot Lights
/31622D*		Control Boxes
/32611D*		Emergency Stop Switches
/32620D*		Enabling Switches
/32622D*		Safety Products
/3B2211D*		Explosion Proof
/3B2220D*		
/3B2222D*		Terminal Blocks
/3B1611D*		Relays & Sockets
/3B1620D*	R	Circuit Protectors
/3B1622D*		Power Supplies
/3B2611D*		LED Illumination
/3B2620D*		Controllers
/3B2622D*		Operator
/42211D*		Interfaces
/42220D*		Sensors
/42222D*		AUTO-ID
/41611D*		
/41620D*	R	
/41622D*		Flush Silhouette
/42611D*	_	ø16
/42620D*	_	
/42622D*		ø22
/4B2211D*		ø30
/4B2220D*		Miniature
/4B2222D*		Pilot Lights
/4B1611D*		
/4B1620D*	R	
/4B1622D*		HW
/4B2611D*		
/4B2620D*		TW
/4B2622D*		YW

Mushroom ø29 / ø40 Pushlock Turn Reset

LED

Shape		Illumination	Rated Voltage	Contact Configuration	Part No.	Color Code	
29mm Mushroom				1NO-1NC	AVLW32211D*		
ushlock Turn Reset VLW3 (*1)			24V AC/DC	2N0	AVLW32220D*		
				2N0-2NC	AVLW32222D*		
<b>Filt</b>	Texas.			1NO-1NC	AVLW31611D*		
		LED	100/110V AC	2N0	AVLW31620D*	R	
				2N0-2NC	AVLW31622D*		
				1NO-1NC	AVLW32611D*		
(24V AC/DC)	With transformer		200/220V AC	2N0	AVLW32620D*		
	(100/110V AC)			2N0-2NC	AVLW32622D*		
9mm Mushroom				1NO-1NC	AVLW3B2211D*		
ıshlock Turn Reset (Marking type) /LW3B (*1)			24V AC/DC	2N0	AVLW3B2220D*		
( .,				2N0-2NC	AVLW3B2222D*		
	Texter			1NO-1NC	AVLW3B1611D*		
		LED	100/110V AC	2N0	AVLW3B1620D*	R	
				2N0-2NC	AVLW3B1622D*	-	
				1NO-1NC	AVLW3B2611D*	-	
(24V AC/DC)	With transformer		200/220V AC	2N0	AVLW3B2620D*		
(211110/00)	(100/110V AC)			2N0-2NC	AVLW3B2622D*		
Omm Mushroom				1NO-1NC	AVLW42211D*		
ıshlock Turn Reset /LW4 (*1)			24V AC/DC	2N0	AVLW42220D*		
				2N0-2NC	AVLW42222D*		
1 de la compañía de l	TP-			1NO-1NC	AVLW41611D*		
		LED			AVLW41620D*	R	
					AVLW41622D*		
				1NO-1NC	AVLW42611D*		
(24V AC/DC)	With transformer		200/220V AC	2N0	AVLW42620D*		
	(100/110V AC)			2N0-2NC	AVLW42622D*		
Omm Mushroom				1NO-1NC	AVLW4B2211D*		
ushlock Turn Reset (Marking type) /LW4B (*1)			24V AC/DC	2N0	AVLW4B2220D*		
				2N0-2NC	AVLW4B2222D*		
Part -				1NO-1NC	AVLW4B1611D*		
		LED	100/110V AC	2N0	AVLW4B1620D*	R	
				2N0-2NC	AVLW4B1622D*		
				1NO-1NC	AVLW4B2611D*		
(24V AC/DC)	With transformer		200/220V AC	2N0	AVLW4B2620D*		
(24V AU/DU)	(100/110V AC)			2N0-2NC	AVLW4B2622D*		

• See **B-265** for marking plate size and engraving area.

• An LED lamp is installed in illuminated pushbuttons unless otherwise specified.

• Round bezel (metal): Mat aluminum color

• See B-236 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC.

• See B-236 for other contact configurations and gold-plated silver contacts.

• Illuminated pushbutttons of 24V AC/DC or below with 2 or 4 contact blocks have a dummy block.]


• See B-236 for how to specify units without LED lamps. When using a commercially available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape. The operation of pilot lights cannot be guaranteed when a commercially available lamp is used.

\*1) AVLW illuminated pushbuttons cannot be used as emergency stop switches. When emergency stop switches are required, use XW or HW series pushbuttons (ISO 13850 and IEC 60947-5-5 compliant).


# **Dimensions**

# Round Extended

6, 12, 24V AC/DC, Without LED lamp




# **Round Extended with Full Shroud**




# Square Extended

6, 12, 24V AC/DC, Without LED lamp




# ø29mm Pushlock Turn Reset


6, 12, 24V AC/DC, Without LED lamp




ø40mm Pushlock Turn Reset 6, 12, 24V AC/DC, Without LED lamp



# Terminal Screw: M3.5, integrated terminal cover




Terminal Screw: M3.5, integrated terminal cover



110V DC, 380V AC minimum

89.5 (2 blocks), 109.5 (4 blocks)


110V DC, 380V AC minimum



Adust ring



Terminal Screw: M3.5, integrated terminal cover 100/110V AC, 200/220V (240V AC maximum)



Terminal Screw: M3.5, integrated terminal cover

Adust ring

Panel thickness

Panel thickness

1 to 6

13

to 6

100/110V AC, 200/220V (240V AC maximum)

Å

79.5 (2 blocks), 99.5 (4 blocks)

79.5 (2 blocks), 99.5 (4 blocks)


Terminal Screw: M3.5, integrated terminal cover

Adust ring

Ð B


Ø

B 110V DC, 380V AC minimum






110V DC, 380V AC minimum





100/110V AC, 200/220V (240V AC maximum) 110V DC, 380V AC minimum





All dimensions in mm.

ess 1 to 6

Panel thickne

.13

APEM

Control Boxes Emergency Stop Switches Enabling

Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Power Supplies LED Illumination

Circuit

Protectors

Controllers

Operator

Interfaces

Sensors AUTO-ID

Flush Silhouette

ø16

ø30

HW

YW

Miniature

Pilot Lights

ø22 TW Series Illuminated Pushbuttons


APEM

Control Boxes

Emergency Stop Switches


# **Bottom View (illuminated)**

6, 12, 24V AC/DC, Without LED lamp




1 contact block

100/110V AC, 200/220V (240V AC maximum)




• See B-267 for wiring.




3 contact blocks

110V DC, 380V AC minimum



For DC-DC Converter types, terminal X1 is  $\oplus$ , X2 is  $\ominus$ .



2/4 contact blocks

Enabling Switches
Safety Products
Explosion Proof
Terminal Blocks
Relays & Sockets
Circuit Protectors
Power Supplies
LED Illumination
Controllers
Operator Interfaces
Sensors
AUTO-ID
Flush Silhouette
ø16
ø22
ø30
Miniature

Pilot Lights

HW

YW

# ø22 TW Series Selector Switches

ASW

Shape

# Selector Switches (Knob Operator)

Knob Operator



APEM Con Sto Safe Expl Term Relay Pow LED I

Flush

HW

YW

1

Control Boxes			Contact	Configurati	on			Maintained	Spring Return from Left						
Emergency Stop Switches		Contact	Contac			ator Pos	sition	1 2	Spring Return from Right $1^{2}$	Contac		Ope	rator ition	1 2	
Enabling Switches		Code	Mounting Position	Contact	1	2		1 2	$\checkmark$	Mounting Position	Contact	1	2	$\checkmark$	
fety Products		1N0	0	NO		•				0	NO	•			
plosion Proof	90°	(10)	2	_	Dur	nmy Bl	ock	ASW210	ASW2110	2	_	_		ASW2210	
	90 <sup>°</sup> 2-position	1N0-1NC	0	NO		•		ASW211	ASW2111	0	NO	•		ASW2211	
rminal Blocks		(11)	2	NC				ASWZTT	ASWZTTT	2	NC			ASWZZTT	
		2N0	0	NO		•		ASW220	ASW2120	0	NO			ASW2220	
ays & Sockets		(20)	2	NO		•		AUNZEU	AGWZTZO	2	NO	•		AGWEELO	
Circuit			0	NO		•				0	NO	•			
Protectors		2N0-2NC	2	NC				ASW222	ASW2122	2	NC			ASW2222	
ower Supplies	(22)		3	NO		•				3	NO				
			4	NC	•					4	NC				
D Illumination			Contac	t Block	Oper	ator Pos	sition	Maintained			Spring Return from Left			Spring Return	
Controllers		Contact Code	Mounting Position	Contact	1	0	2		from Right $1 \int_{1}^{0} 2^{2}$	1 0 2				Two-way $1 < 1 > 2$	
Operator Interfaces		2N0	1 031001	NO	•			•	•		•		_	•	
		(20)	 	NO	-		•	ASW320	ASW3120	ASW3220		ASW3220		ASW3320	
Sensors		2NC	0	NC			<b>—</b>								
AUTO-ID		(02)	2	NC				ASW302	ASW3102		ASW3202			ASW3302	
		,	0	NO	•										
		2N0-2NC	2	NO			•	1011/000	10110100		10110000			1011/0000	
		(22)	3	NC				ASW322	ASW3122		ASW3222			ASW3322	
ish Silhouette	45°		4	NC											
ISH SIMOUELLE	3-position		0	NO	٠										
ø16		4N0	2	NO			•	ASW340	ASW3140		ASW3240			ASW3340	
		(40)	3	NO				A3W340	A3W3140		A3W3240			A3W3340	
ø22			4	NO			•								
ø30			0	NC											
Ø3U		4NC	2	NC				ASW304	ASW3104		ASW3204			ASW3304	
Miniature		(04)	3	NC				A01004	A3W3104		A0110204			A3W3304	
			4	NC											
Pilot Lights			0	NO	•										
		3S☆	2	NO			•	$\overrightarrow{a}$	_		_			_	
		00 4	3	NC				ASW33S-243					_		
			4	_	Dur	nmy Bl	ock								

. Knob operator: white indicator on black body

• Cylinder: Mat aluminum color

• Selector switches with one or three contact blocks contain a dummy block.

Spring return is not available with contact code 3S.

• On the contact arrangement marked with 🕸 in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

 $\bullet$  For models with  $\precsim$  , contacts may overlap when the operator position is changed.

• Other contact arrangements are also available. See B-253 to B-255.

• Optional selector operators and color inserts are available.


• See B-236 for gold-plated silver contacts.

• Turn the operator to each position accurately.

# **Contact Block Mounting Position**

# Dimensions





All dimensions in mm.

Terminal screw: M3.5 Integrated terminal cover

See B-238 for bottom view.

# For more information, visit http://asia.idec.com

**Contact Configuration** 

Contact

NO

**Operator Position** 

•

Dummy Block

Contact Block

Mounting

Position

1

2

Lever Operator ASW□L

Contact

Code

1N0

(10)

Shape

90°

**Switches & Pilot Lights** Package Quantity: 1 APEM Control Boxes Spring Return from Spring Return from Left Emergency Operator **Contact Block** Stop Switches Position  $\frac{1}{2}$ Enabling Mounting Switches Contact 1 2 Position Safety Products 1 NO • ASW21L10 ASW22L10 2 Explosion Proof NO • 1 ASW22I 11 al Blocks & Sockets ors Supplies mination lers es

90	1N0-1NC	0	NO						0	NO						
2-position	(11)	2	NC	•	_		ASW2L11	ASW21L11	2	NC	-	•	ASW22L11	Terminal Blocks		
	2N0	1	NO					ACW011.00	1	NO						
	(20)	2	NO				ASW2L20	ASW21L20	2	NO			ASW22L20	Relays & Sockets		
		0	NO		•				0	NO				Circuit		
	2N0-2NC	2	NC				ASW2L22	ASW21L22	2	NC			ASW22L22	Protectors		
	(22)	3	NO				AGWZLZZ	ASWZILZZ	3	NO			AGWZZLZZ	Power Supplies		
		4	NC						4	NC						
	Contact	Contac	t Block	Operator Position		Operator Position		tion	Maintained	Spring Return from Right	Sprin	g Return fro	m Lef	t	Spring Return Two-way	LED Illumination
	Code	Mounting Position	Contact	1	0	2								Controllers Operator		
	2N0	0	NO	•			ACW01.00	ACW21L00		ACM001.00	<u> </u>		101/1021 00	Interfaces		
	(20)	2	NO			•	ASW3L20	ASW31L20		ASW32L20	)		ASW33L20	Sensors		
	2NC	1	NC				ASW3L02	ASW31L02		ASW32L02	)		ASW33L02	- <u></u>		
	(02)	2	NC				ASWJLUZ	ASWSTEDZ		AGWJZLUZ	-		ASWSSLUZ	AUTO-ID		
		0	NO	•												
	2N0-2NC	2	NO			•	ASW3L22	ASW31L22		ASW32L22	)		ASW33L22			
	(22)	3	NC													
45°		4	NC											Flush Silhouette		
3-position		0	NO	•		_										
	4N0	2	NO			•	ASW3L40	ASW31L40		ASW32L40	)		ASW33L40	ø16		
	(40)	3 (4)	NO NO	•		•								ø22		
		(4) (1)	NC			-								022		
	4NC	2	NC											ø30		
	(04)	3	NC				ASW3L04	ASW31L04		ASW32L04	ł.		ASW33L04			
		4	NC			_								Miniature		
		0	NO	•										Pilot Lights		
		2	NO			•	\$									
	3S ☆	3	NC		•		ASW3L3S-243	_		_						

Maintained

2

ASW2L10

Right

 $\frac{1}{2}$ 

• Lever operator: white indicator on black body

• Cylinder: Mat aluminum color

• Selector switches with one or three contact blocks contain a dummy block.

• Spring return is not available with contact code 3S.

• On the contact arrangement marked with 🌣 in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

• For models with  $rac{l}{\sim}$ , contacts may overlap when the operator position is changed.

• Other contact arrangements are also available. See B-253 to B-255.


• Optional selector operators and color inserts are available.

• See B-236 for gold-plated silver contacts.

• Turn the operator to each position accurately.

# **Contact Block Mounting Position**

# Dimensions



HW

YW

Contact Code

Operator

Position

1 2

Key Selector Switch ASW□K (Key No. 0)

Mounting

Position

Shape

Switches & Pilot Lights

	APEM
	Switches & Pilot Lights
	Control Boxes
	Emergency Stop Switches Enabling
	Switches
	Safety Products
90° 2-positi	Explosion Proof
2 00010	Terminal Blocks
	Relays & Sockets
	Circuit Protectors
	Power Supplies
	LED Illumination
	Controllers
	Operator Interfaces
	Sensors
	AUTO-ID
	Flush Silhouette
45° 3-positi	ø16
o poorti	ø22
	ø30
	Miniature
	Pilot Lights
	HW
	TW

Contact	Configurat	tion			Maintained	Spring Return	Spring	, Return fro	m Lef	t
Contact			sition	1 2	from Right $\frac{1}{2}$	Contac	t Block	Operat Positio		
Mounting Position	Contact	1	2		$\sim$		Mounting Position	Contact	1	
1	NO		•		ASW2K10	ASW21K10	0	NO	•	
2	—	Dur	nmy B	lock	ASWZKIU	ASWZIKIU	2		-	_
1	NO		•		ASW2K11	ASW21K11	0	NO	•	
2	NC				ASWZKII	ASWZIKII	2	NC		
1	NO		•		ASW2K20	ASW21K20	0	NO	•	
2	NO		•		ASWZKZU	ASWZIKZU	2	NO	•	
0	NO		•				0	NO	•	
2	NC	•			ASW2K22	ASW21K22	2	NC		
3	NO		•	1	ASWZKZZ	AOWZINZZ	3	NO	•	
(4)	NC			1		1	(4)	NC		

	1N0	0	NO				ASW2K10	ASW21K10	0	NO			ASW22K10		
	(10)	2	—	Dur	nmy B	lock	ASWZKIU	ASWZIKIU	2	_	-	_	ASWZZKIU		
90°	1N0-1NC	0	NO				ASW2K11	ASW21K11	0	NO			ASW22K11		
2-position	(11)	2	NC				ASWZKII	ASWZIKII	2	NC			ASWZZKII		
	2N0	0	NO				ASW2K20 ASW21K20		ASW22K20						
	(20)	2	NO		•		ASWZNZO	ASWZINZU	2	NO			ASWZZNZO		
		0	NO						0	NO					
	2N0-2NC	2	NC				ASW2K22	ASW21K22	2	NC			ASW22K22		
	(22)	3	NO		•		AGWZNZZ	ASWZINZZ	3	NO			AGWZZNZZ		
		4	NC						4	NC					
	Contact	Contac	t Block	Opera	ator Po	osition	Maintained	Spring Return	Spring	g Return fro	m Lef	t	Spring Return		
	Code	Mounting Position	Contact	1	0	2		from Right $1 - \frac{1}{2} - \frac{1}{2}$				Two-way			
	2N0	0	NO	•			ASW3K20 ASW31K20 ASW32K20				ASW32K20				
	(20)	2	NO			•	A5W3K20	ASWSTKZU		ASW32K2U		ASW33K20			
	2NC	0	NC				ASW3K02	ASW31K02		ASW32K02	)		ASW33K02		
	(02)	2	NC				ASWSKUZ	ASWSTRUZ		ASWSZKUZ	ASWSSKUZ				
		0	NO												
	2N0-2NC	2	NO				ASW3K22	ASW31K22		ASW32K22		ASW33K22			
	(22)	3	NC				ASWSILZ	ASWSTRZZ		AGWJZNZZ			ASWJJKZZ		
45°		4	NC												
3-position		0	NO	•											
	4N0	2	NO				ASW3K40	ASW31K40		ASW32K40			ASW33K40		
	(40)	3	NO	•			701010	70101140		701021140			70100140		
		4	NO			•									
		0	NC												
	4NC	2	NC				ASW3K04	ASW31K04		ASW32K04			ASW33K04		
	(04)	3	NC				AGNOROT	Admontor		AUW02N04			AGWOORD		
		4	NC												
		0	NO	•											
	3S ☆	2	NO				☆	_					_		
		3	NC		•	ASW3K3S-243									

· Cylinder cover: black

YW

• Cylinder: Mat aluminum color

• On the spring-returned types, the key can be released only from the maintained position. On the maintained types, the key can be released from every position. Other key retained positions are also available. See B-236.

Dummy Block

· Selector switches with one or three contact blocks contain a dummy block.

(4)

- On the contact arrangement marked with  $\precsim$  in the table above, the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

- For models with  ${\rm tr}$ , contacts may overlap when the operator position is changed. • Other contact arrangements are also available. See B-253 to B-255.

• See B-236 for gold-plated silver contacts.

• Key selector switch is supplied with two standard keys.


(1) Insert the key completely before turning the key, otherwise failure may result. (2) Turn the operator to each position accurately.

· Different key number is available upon request. Contact IDEC.

# **Contact Block Mounting Position**



# Dimensions



All dimensions in mm.


Terminal screw: M3.5 Integrated terminal cover

See B-238 for bottom view.

# For more information, visit http://asia.idec.com

LED

# Illuminated Selector Switches



Turn the operator to each position accurately.

· See B-237 for gold-plated silver contacts.

commercially available lamp is used.

• See B-253 to B-255 for other contact arrangements.

See B-237 for how to specify units without LED lamps. When using a commercially

available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape. The operation of pilot lights cannot be guaranteed when a

• Specify a color code in place of \* in Part No. R (red), G (green), Y (yellow), A (amber), S (blue), PW (pure white)


 An LED lamp is installed in illuminated selector switches unless otherwise specified. · Round bezel (metal): Mat aluminum color

• See B-237 for other operating voltage such as 6V AC/DC, 12V AC/DC, and 110V DC. · Illuminated selector switches of 24V AC/DC or below with 2 or 4 contact blocks have a

dummy block.

# **Contact Block Mounting Position**





89.5 (2 blocks)

Terminal screw: M3.5 Integrated terminal cover

• See B-248 for bottom view.

109.5 (4 blocks

ø30

HW

YW

Miniature

Pilot Lights

# Selector Switch Contact Arrangement

# 90° 2-position

Switches & Pil

<u> </u>	30 Z P	001001	•																					
Ê					Operator Operation and Circuit Availability																			
lot Lights									ing re				eturn											
No.			Cont	tact	Ma 1	lintain	ed 2	fr   1	om rig	iht 2		rom I	left 2		(	Operator	Availability (*1)							
			Blo	ck		$\checkmark$			$\searrow$	>-			/											
APEM	Contact Code	Circuit No.			Knob/	Key	Illuminated	Knob/	Key	Illuminated	Knob/	Key	/ Illuminated				Illumi	Illuminated						
Switches & Pilot Lights					Lever	NOY	mummateu	Lever	NOY	munnatou	Lever	NO	/ IIIUIIIIIateu	Knoh	Lovor	vor Kov								
Control Boxes			Mounting Position	Contact	1		2	1		2	1		2	Knob	Lever	Кеу	6V, 12V, 24V AC/DC	100/110V AC 200/220V AC						
Emergency Stop Switches			FUSILIUII		8		Ø		>	Ø	<b>N</b>	>	Ø				AC/DC	200/220V AC						
Enabling Switches	10		0	NO			•		+	•	•			×	×	×	~							
Safety Products	10		2		Dun	ımy B	lock		nmy B	llock	Dummy Block				×	×	_							
Explosion Proof	01	_	0 2	NC	● Dum	Dummy Block		-	Dummy Block		Dummy Block		×	×	×	×	_							
Terminal Blocks	11		0	NO	•			•		•		bioon	×	×	×	×	×							
Relays & Sockets			2	NC	•			•					•	~	<u>^</u>			^						
Circuit	20	_	0	NO			•			•	•			×	×	×	×	×						
Protectors			2 1	NO NC	•	_	•	•		•	•	_	•											
Power Supplies	02	—	0 0	NC	•	+		•					•	×	×	×	×	×						
LED Illumination			0	NO			•			•	•													
Controllers	22		2	NC	•			•					•	×	×	×	×	×						
Operator			3	NO			•			•	•													
Interfaces			4	NC									•											
Sensors			0	NC	•	_	-						•											
	31	107	2 3	NO NO		_	•		_	•	•	_		×	×	×	×	×						
AUTO-ID			(3) (4)	NO		+	•		_	•	•													
			0	NO			•			•	•													
			 	NO			•			•	•													
Flush Silhouette	40	-	3	NO		+	•			•	•	-		×	×	×	×	×						
			4	NO			•			•	•													
ø16	\$	☆	0	EM					-															
ø22		118	2	LB		-	-		-	)				×	×	×	×	×						
a00	2R	\$	0	EM										×	×	×	×	×						
ø30		168	2	LB								-												
Miniature	- On the			ما بيم مير ا	_\ مانان ا		table ab		+		امم المعام		mt (laad au	uitah in a			d to a half of th							




• On the contact arrangement marked with 🕸 in the table above (contact code: 2R), the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

 $\bullet$  For models with  $\precsim$  , contacts may overlap when the operator is changed.



# **Contact Block Mounting Position** 4 2 TW mark TW mark facing up

# **Ordering Information**



2: 2-position/maintained


- 21: 2-position/spring return from right
- 22: 2-position/spring return from left

Contact Code 1	Circuit No.	Mounting Position						rcuit Availability Operator Availability (*1)				Circuit Availability							ilot Lights
		Mounting											Illumi	inated					
11		FUSILIOII	Contact		0 (1)	2 Ø	Knob/ Lever	Кеу	Illuminated	Knob	Lever	Key	6V, 12V, 24V AC/DC	100/110V AC 200/220V AC	APEM				
11				Ů		$\sim$									Switches & Pilot Lights				
11	202	0 2	NO NC	•			- x x x x x x				×			×	Control Boxes				
	203	0	NC		-			×		×	×	×	×	×	Emergency Stop Switches				
	200	2 1	NO NC		•	•									Enabling Switches				
	303	@	NO		•	•	×			×	×	×	×	×	Safety Products				
20	_	0	NO	•				×		×	×	×	×	×	Explosion Proof				
		2 ①	NO NC			•									Terminal Blocks				
02	—	@	NC					×		×	×	×	×	×					
		0	NO	•						×	×	×	×	×	Relays & Sockets				
	_	2 3	NO NC			•		×							Protectors				
		 	NC							×	×	×	×	×	Power Supplies				
		0	NC							×	×	×	×	×	LED Illumination				
22	210	2	NO			•		×		~		~	^	^	Controllers				
		3 4	NC NO			•				×	×	×	×	×	Operator				
		0	NC		•					×	×	×	×	×	Interfaces				
	310	0	NO			•		×		^	<u>^</u>	^	<u>^</u>	^	Sensors				
		3 4	NC NO		•	•				×	×	×	×	×	AUTO-ID				
		(4) (1)	NC																
	007	@ 	NO			•		~		×	×	×	×	×					
31	207	3	NO	•				×		×	×	×	×	×	Flush Silhouette				
		4	NO			•				~	^	^	^	^	ø16				
		0	NO	•						×	×	×	×	×					
40	_	2	NO	•		•		×							ø22				
		3 (4)	NO NO	•		•				×	×	×	×	×	ø30				
		0	NC							×	×	×	×	×	Miniature				
04	_	2	NC					×							Pilot Lights				
		3 (4)	NC NC							×	×	×	×	×					

# 45° 3-position <Maintained / Spring Return from Right / Spring Return from Left / Spring Return Two-way>

# **Contact Block Mounting Position**





**Ordering Information** 

No. of positions/operator operation

L: Lever K: Key

3: 3-position/maintained

33: 3-position/spring return two-way

31: 3-position/spring return from right 32: 3-position/spring return from left


HW


YW

# ø22 TW Series Selector Switch Contact Arrangement Chart

# 45° 3-position (Maintained)

<b>Q</b> 0	10 0 0	Jonatoni	(maintai	100)										
& Pilot Lights						Operator Operation and Circuit								
E.			Contact		М	laintaine	ed		(	)perator	Availability			
yhts	Contact	Circuit		Block										
	Code	No.			Opera	ator Pos	itions		b Lever		Illuminated			
APEM			Mounting		1	0	2	Knob		Key	6, 12, 24V	100/110V AC		
Switches & Pilot Lights			Position	Contact	۲		Ø				AC/DC	200/220V AC		
Control Boxes	45		0	NO	•									
Emergency	3S <sup>☆</sup>	243	2	NO		-	•	×	×	×	×	_		
Stop Switches			3	NC	Du		a al í							
Enabling			(4)	NO	Du	mmy Bl	OCK							
Switches			 	LB					×	×				
Safety Products		234	3	NC				×			×	×		
			4	LB										
Explosion Proof			0	NO	•									
Terminal Blocks	4S <sup>☆</sup>	237	2	NO				×	x	×	×	×		
Terminal blocks	45	237	3	NC				^	^	^		^		
Relays & Sockets			4	NO										
-			0	LB										
Circuit Protectors		240	2	LB				×	×	×	×	×		
Power Supplies			3 4	NC NO		•								
	L													





## LED Illumination 45° 4-position (Maintained)

Controllers					Opera	tor Opera	tion and (	Circuit																																				
Operator			Cant	<b>.</b>		Main		Operator																																				
Interfaces			Cont Bloo			1 2		Operator Availability																																				
Sensors	Contact	Circuit	DIUC	5n		$\sim$																																						
	Code	No.				Operator	Positions																																					
AUTO-ID			Mounting		1	2	3	4																																				
			Position	Contact					Knob	Lever																																		
			1 0310011		$\sim$		$\bigtriangledown$	$\sim$																																				
			0	LB																																								
Fluck Ollhaustha		107	2	NC					×	×																																		
Flush Silhouette		407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	407	3	NC					- ×	^
ø16	\$		4	NO																																								
ØIO	4S 411		0	NO	•																																							
ø22		411	2	NC		•			×	×																																		
922		3	NC					^																																				
ø30				NO																																								


### Miniature 30° 5-position (Maintained)

	00 0 pt												
Pilot Lights					(	Operator C	peration a	and Circui	t				
	Contact Code	Circuit	Contact Block			Γ	Maintained	ł		Operator Availability			
HW	Code	No.				Oper							
1100		Mounting		1	2	3	4	5					
τw			Mounting Position	Contact	8	۲		Ø	۲	Knob	Lever		
YW			0	NO	•								
	4S <sup>☆</sup>	501	2	NC		•				×			
	40	501	3	3 NC				•		^	×		
			4	NO					•				

• On the contact arrangement marked with 🕸 in the table above (contact code: 3S, 4S), the rated current (load switching current) is reduced to a half of the related current of the contact block. The rated insulation voltage and the rated thermal current remain unchanged.

• For models with  $\Rightarrow$ , contacts may overlap when the operator is changed.

# **Ordering Information** ASW 4 L 4S - 407



5: 5-position/maintained

**Contact Block Mounting Position** 



# ø22 TW Series Accessories

Nameplates						ies & Pilot Lights
					All dimensions in mm.	Pilo
Shape	Legend	Material	Part No.	Ordering No.	Package Quantity	t Lig
NWA				NWA-0	1	nts
	Blank	Alunimum (black)	NWA-0	NWA-0PN10	10	
		(Legend: white)		NWA-	1	APEM
0.8 mm thick	With Legend		NWA-□	NWA-□PN10	10	Switches & Pilot Lights
NWAQ				NWAQ-0	1	Control Boxes
	Blank	Alunimum (black)	NWAQ-0	NWAQ-0PN10	10	Emergency Stop Switches
14.5		(Legend: white)		NWAQ-	1	Enabling Switches
.8 mm thick	With Legend		NWAQ-□	NWAQ-□PN10	10	Safety Products
NWAS				-	+	Explosion Proof
				NWAS-0	1	Terminal Blocks
42	Blank	Alunimum (black)	NWAS-0		+	Relays & Sockets
0.8 mm thick				NWAS-0PN10	10	Circuit Protectors
NWAL					+	Power Supplies
29>				NWAL-0	1	LED Illumination
- 25	Blank	Alunimum (black)	NWAL-0		+	Controllers
0.8 mm thick				NWAL-0PN10	10	Operator Interfaces
NWAQL				-	+	Sensors
29→				NWAQL-0	1	AUTO-ID
22	Blank	Alunimum (black)	NWAQL-0		+	
0.8 mm thick				NWAQL-0PN10	10	
						Flush Silhouette

 $\bullet$  Specify a legend code in place of  $\Box$  in the Ordering No.

• The nameplates are used for TW series only.


# Legends

Code	Legend
1	ON
2	OFF
3	START
4	STOP
31	OFF ON
35	HAND AUTO
53	HAND OFF AUTO

ø16
ø22
ø30
Miniature
Pilot Lights

# ø22 TW Series Accessories

hes & Pilot Lights	ŀ	Accessories					
Pilot							All dimensions in mm.
: Ligh		Shape	Material	Part No.	Ordering No.	Package Quantity	Dimensions
APEM		Locking Ring Wrench	Nitryl rubber	0R-14	0R-14	1	• Used to tighten the round bezel when installing the TW switch onto a panel.
Switches & Pilot Lights Control Boxes		B					For ø25 series For ø22 series
Emergency Stop Switches Enabling Switches Safety Products Explosion Proof	Tool	Lamp Holder Tool	Nitryl rubber	OR-55	0R-55	1	Used to install and remove the LED lamps. See B-266 for how to install.     (A) : BA9S     (B)     (CR-55     (CR-56     (CR-55     (CR-56      (CR-56     (CR-5
Terminal Blocks Relays & Sockets Circuit Protectors Power Supplies	F	Contact Block Removal Tool	Zinc-plated metal Nitryl rubber	TW-KC1	TW-KC1	1	• Used to remove the transformer, to install/ remove the waterproof lens and pilot light lens. Can also be used to determine panel thickness (1, 1.6, 2, 2.3, 3.2, 5 mm).
LED Illumination Controllers Operator Interfaces Sensors		Nut Locking Wrench	Metal (nickel-plated)	TW-KQ2	TW-KQ2	1	• Used to tighten the locking nuts inside of the square bezel. This tool can be inserted into the OR-14 locking ring wrench.
AUTO-ID Flush Silhouette ø16	Ant	ti-rotation Ring	Metal (zinc-plated)	0GL-31	OGL-31PN10	10	<ul> <li>Used to prevent the operator from turning. Generally used when using no nameplates on selector switches.</li> <li>Installed on the front of panel.</li> </ul>
ø10 ø22 ø30 Miniature Pilot Lights	Rul	bber Mounting Hole Plug	Nitril rubber (black)	OB-31	0B-31PN05	5	<ul> <li>Used to plug unused ø22.2mm mounting holes.</li> <li>Degree of protection:</li> <li>IP65 (round mounting hole)</li> <li>IP40 (with anti-rotation function)</li> </ul>
HW TW YW	Me	tallic Mounting Hole Plug	Plug: chrome-plated zinc diecast Locking ring: polyamide	LW9Z-BM	LW9Z-BM	1	Used to plug the unused ø22.2 mm mounting holes. Degree of protection: IP66 (round hole) IP40 (with anti-rotation function) Tightening torque: 1.2 N·m
	Pla	stic Mounting Hole Plug	Polyamide (black)	LW9Z-BP1	LW9Z-BP1	1	• Used to plug the unused ø22.2 mm mounting holes. Degree of protection: IP65 Tightening torque: 2.0 N·m
	Bai	rrier	Polyamide	HW-VU1	HW-VU1PN10	10	Used to prevent contact between adjacent lead wires when units are mounted closely (see B-266 for details). Barriers should always be used in close mounting.



# ø22 TW Series Accessories

les &	Accessories								
Pilot								All dimensions in mm.	
nes & Pilot Lights	Shape		Material	Part No.	Ordering No.	Packaging Quantity		Remarks/Dimensions	
CC APEM Switches & Pilot Lights	Ring Adapter		Nitryl rubber	HW9Z-A25	HW9Z-25PN05	5	<ul> <li>Used to install the TW series units into ø25 mm mounting holes.</li> <li>IP65</li> <li>Cannot be used with anti-rotation and nameplate.</li> <li>Mounting panel thickness: 1.2 to 5.5 mm</li> <li>See B-265 for details.</li> </ul>		
Control Boxes Emergency	Plastic Bezel	1 Flush		AW-RP1B	AW-RP1BPN05	5		①/⑦Flush ②/⑧Extended	
Stop Switches Enabling Switches		② Extended		AW-FP1B	AW-FP1B	1			
Safety Products Explosion Proof		<ul> <li>③ Extended (for illuminated pushbuttons)</li> </ul>	Polyacetal (black)	AW-FP2B	AW-FP2B	1		③/⑨ ④ Square round Extended (For lens) □30	
Terminal Blocks Relays & Sockets	5	<ul> <li>④ Square round (for round buttons)</li> </ul>		AW-H1B	AW-H1B	1	Supplied with base plate		
Circuit Protectors Power Supplies		© Square	-	AW-Q1B	AW-Q1B	1	and locking ring	©Square @ Mushroom	
LED Illumination	Aluminum Bezel 7 ®			AW-R1	AW-R1PN05	5	Aluminum color		
Controllers Operator Interfaces	88	⑦ Flush	Aluminum	AW-R1B	AW-R1B	1	Black		
Sensors AUTO-ID		® Extended		AW-F1	AW-F1	1	Aluminum color		
A010-ID				AW-F2	AW-F2	1	Aluminum color		
Flush Silhouette		<sup>®</sup> Mushroom		AW-G4	AW-G4	1	Aluminum color		
ø16 ø22	Selector Operator	① Knob		ASWHHY-*	ASWHHY-*PN02	2	Specify a color B (black), G (gr ø23.4, H19	code in place * in Ordering No. een), R (red)	
ø30 Miniature	2 2	② Lever	Polyacetal	ASWHHL-*	ASWHHL-*PN02	2	Specify a color B (black), G (gr ø23.4, H19	code in place * in Ordering No. een), R (red)	
Pilot Lights		③ Round		ASWHHM-B	ASWHHM-BPN02	2	Black only, ø23	8.4, H18.5	
HW	3	④ Color Insert	Polyacetal	TW-HC1*	TW-HC1*PN05	5		code in place * in Ordering No. een), R (red), Y (yellow), S (blue),	
TW YW	5	© Illuminated	AS resin	ASLWDDY-*	ASLWDDY-*	1		code in place * in Ordering No. ellow), W (white)	
		Selector	0-ring: nitryl rubber	ASLWLDY-*	ASLWLDY-*	1	Specify a color R (red), G (gree ø20.6, H19.6	code in place * in Ordering No. en), S (blue)	
	Metal Protector		Metal (zinc coated steel)	OLW-C	OLW-C	1	Used to protec flush pushbuttd from inadverte operation. Weight: 36.5g	ons $\frac{9}{60}$ / $\frac{18.6}{18.6}$	

# Maintenance Parts

		1				All dimensions in mm.			
Shaj	pe	Material	Part No.	Ordering No.	Packaging Quantity	Color Code	Pilot Lights		
Lens (for pilot lights)	①Round flush		APW1L-*	APW1L-*PN05		R (red), G (green), S (blue)	ο Ο		
1 2			APW1LD-*	APW1LD-*PN05		A (amber), Y (yellow), W (white)			
	②Round flush	AS resin	APW11LN-*	APW11LN-*PN05		R (red), G (green), S (blue), C (clear) (*1)	APEM		
	(marking type)	①ø23.6, H12.7 ②ø23.6, H12.7	APW11LD-*	APW11LD-*PN05	5	A (amber), Y (yellow),	Switches &		
3 4	③Round extended	3ø23.6, H20.0	APW2L-*	APW2L-*PN05		R (red), G (green), S (blue)	Pilot Lights Control Boxes		
			APW2LD-*	APW2LD-*PN05		A (amber), Y (yellow), W (white)	Emergency		
	④Square flush		APQW11L-*	APQW11L-*PN05		R (red), G (green), S (blue), C (clear) (*1)	Stop Switches		
			APQW11LD-*	APQW11LD-*PN05		A (amber), Y (yellow),	Enabling Switches		
Lens (for illuminated	①Round extended		ALW2L-*	ALW2L-*PN05		R (red), G (green), S (blue)	Safety Products		
1 2		AS resin	ALW2LD-*	ALW2LD-*PN05		A (amber), Y (yellow), W (white)	Explosion Proof		
	②Round extended	10ø23.6, H8.6	ALW21L-*	ALW21L-*PN05	5	R (red), G (green), S (blue), C (clear) (*1)			
	(marking type)	2ø23.6, H8.6 ③□24.8, H9.6	ALW21LD-*	ALW21LD-*PN05	5	A (amber), Y (yellow),	Terminal Blocks		
3 4	3Square extended	◎□24.0, 119.0	ALQW21L-*	ALQW21L-*PN05		R (red), G (green), S (blue), C (clear) (*1)	Relays & Sockets		
	Square extended		ALQW21LD-*	ALQW21LD-*PN05		A (amber), Y (yellow),	Circuit Protectors		
	<b>④ø29 Mushroom lens</b>	@ a 20 0/a 22 6 111 2 7	AVLW3L-R	AVLW3L-RPN02			Power Supplies		
5		@ø29.0/ø23.6 H12.7	AVLW31L-R	AVLW31L-RPN02	0	Marking type	LED Illumination		
	©¢40 Muchroom long	©ø40.0/ø23.6 H12.5	AVLW4L-R	AVLW4L-RPN02	2				
	5ø40 Mushroom lens	3040.0/023.0 HT2.3	AVLW41L-R	AVLW41L-RPN02		Marking type	Controllers		
Button	①Round/Square round Flush		ABW1B-*	ABW1B-*PN05			Operator Interfaces Sensors		
	②Round/Square round Extended		ABW2B-*	ABW2B-*PN05	- 5		AUTO-ID		
<b>(4</b> )	3Square Flush	Polyacetal	ABQW1B-*	ABQW1B-*PN05		B (black), G (green), R (red), Y (yellow),			
6	④Square Extended	(0¢23.6, H3 (4.8) (0¢23.6, H9.5 (11.5) (3) (24.8, H1.5 (3.0) (4) (24.8, H8 (9.5)) (5) (6) (29 H12.5)	ABQW2B-*	ABQW2B-*PN05		S (blue), W (white)	Flush Silhouette		
	©ø29 Mushroom button unit		ABW3B-*	ABW3B-*PN02			ø16		
8	©ø40 Mushroom button unit	©ø40 H12.5 Øø29.0/ø23.6, H12.7	ABW4B-*	ABW4B-*PN02			ø22		
	Ø29 Mushroom pushlock turn reset	8ø40.0/ø23.6, H12.5 9ø40/ø23.6, H20.2	AVW3B-*	AVW3B-*PN02	2	R (red), Y (yellow)	ø30 Miniature		
	®ø40 Mushroom pushlock turn reset	1®ø40/ø23.6, H14	AVW4B-*	AVW4B-*PN02	-	R (red), Y (yellow)	Pilot Lights		
	<pre> ⑨ø40 Mushroom push pull </pre>		AYW4B-*	AYW4B-*PN02		B (black), G (green), R (red), Y (yellow), S (blue), W (white)	- <u></u>		
	10000000000000000000000000000000000000		AXW4B-R	AXW4B-RPN02			HW		
Marking Plate (for pilot lights) ① ②	①Round flush	Acrylic 10017.2, H8.5	APW2B	APW2BPN05			TW		
	②Square flush (UPQW)	©©17.2,118.5 ©□22.0, H2.6	APQW1B	APQW1BPN05			YW		
Marking Plate (for illuminated pushbuttons)	①Round extended/ Round extended with full shroud	Acrulic	ALW2B	ALW2BPN05	5	White See <mark>B-265</mark> for dimensions.			
2 3	<sup>②</sup> Square extended	Acrylic ①ø17.0, H6.4 ②□21.0, H4.4 ③ø15.7, H3.4	ALQW2B	ALQW2BPN05					
	③ø29 Mushroom ø40 Mushroom		ALW3B	ALW3BPN05					
Waterproof Lens ① ②	() UPQW	Acrylic 10ø21.8, H7.1	APW00LN	APW00LNPN05	5				
$\bigcirc$	②ALQW	©ø21.8, 117.1 ©ø20.6, H5.6	APW00L	APW00LPN05	5				

\*1) Use a C (clear) lens for PW (pure white) illumination.

# **Maintenance Parts**

Switches &

Pilo												
Pilot Lights	Shape	Specification	Part No.	Ordering No.	Packaging Quantity	Remarks						
5	Contact Block	1NO	HW-U10	HW-U10	1	Housing color: Blue Push rod color: Green						
	HW-U	INO	HW-U10-MAU	HW-U10-MAU	I	MAU has gold contacts						
APEM	San San	1NC	HW-U01	HW-U01	1	Housing color: Reddish purple Push rod color: Red						
Switches & Pilot Lights			HW-U01-MAU	HW-U01-MAU	1	MAU has gold contacts						
Control Boxes		EM contact	HW-U10R	HW-U10R	1	Housing color: Blue Push rod color: Black						
Emergency		(early make contact)	HW-U10R-MAU	HW-U10R-MAU	I	MAU has gold contacts						
Stop Switches Enabling		LB	HW-U01R	HW-U01R	1	Housing color: Reddish purple Push rod color: White						
Switches	Weight: 11g (approx.)	(late break contact)	HW-U01R-MAU	HW-U01R-MAU	I	MAU has gold contacts						
Safety Products	Dummy Block					For HW-U contact blocks						
Explosion Proof	Weight: 3.5g	Polyamide	HW-DB	HW-DBPN10	10	Used when the total number of contact						
Terminal Blocks	(approx.)					blocks and full voltage adapters is odd.						
Relays & Sockets	Full Voltage Adapter					Applicable model: Illuminated pushbuttons						
Circuit Protectors	For illuminated unit (*1)					Illuminated selector switches						
Protectors Power Supplies	<b>S</b>	Polyamide	HW-GA1N	HW-GA1N HW-GA1NPN02	HW-GA1NPN02	2	Applicable load (LED lamp) LSTD-6 (6V AC/DC)					
	Weight: 12g (approx.)					LSTD-1 (12V AC/DC) LSTD-2 (24V AC/DC)						
LED Illumination	Transformer Unit (*1)					Applicable model:						
Controllers		100/110V AC	HW-T16	HW-T16	1	Pilot lights Illuminated pushbuttons						
Operator Interfaces	Weight: 65g					Illuminated selector switches						
Sensors	(approx.)	200/220V AC	HW-T26	HW-T26	1	Applicable load (LED lamp) LSTD-6 (6V AC/DC)						
AUTO-ID	Spare Key					Applicable model:						
	Length 39 Width 19.7 Thickness 1.8	Metal (nickel-plated brass)	TW-SK-0	TW-SK-0PN02	2	Key selector switches Pushlock key reset						
	Contact Block Plug											
Flush Silhouette		Polyamide	HW9Z-CBPL	HW9Z-CBPLPN10	10	Used to plug the hole in the center of contact block.						
ø16												

\*1) For use as maintenance parts. Do not use for expansion or remodelling purposes.

# **TW Series LED Lamps**

ø30

		•							
Miniature	Shape/Dimensions	Rated Voltage	Current Draw		Part No.	Ordering No.	Color Code	Package	Base
Dilativation	onapo, Dimensiono	natou vonago	DC	AC	Turt No.	ordoning No.	00101 0000	Quantity	Dube
Pilot Lights			7 mA (R, A, W) 5 5 mA (C, DM) 8 mA (except S)			LSTD-6*	R, G, A, W, S, PW	1	
		6V AC/DC	5.5 mA (G, PW) 4.5 mA (S)	7 mA (S)	LSTD-6	LSTD-6*PN10	R, G, A, W, S, PW	10	
	(20.8)			11 mA (except S)		LSTD-1*	R, G, A, W, S, PW	1	
HW	2.4 18.4	12V AC/DC	10 mA (except S)	9 mA (S)	LSTD-1				BA9S/13
	Grommet (X1)		8 mA (S)	9 IIIA (3)		LSTD-1*PN10	R, G, A, W, S, PW	10	
TW	Base (X2)	24V AC/DC	10 mA (except S)	11 mA (except S)	LSTD-2	LSTD-2*	R, G, A, W, S, PW	1	
YW	BA9S/13 Voltage	24V AC/DC 8 mA (S)		9 mA (S)	L31D-2	LSTD-2*PN10	R, G, A, W, S, PW	10	

• Specify a color code in place of \* in Ordering No. R (red), G (green), A (amber), W (white), S (blue), PW (pure white)

• Use a PW (pure white) LED for Y (yellow ) illumination.

# LED lamps for replacing incandescent lamps

• Use the following replacement LED lamps to replace incandescent lamps.

• See TW series LED lamps shown above for ordering.

• LED lamps may have different brightness/color hue compared with incandescent lamps.

Model (mm)	Part No.				
LS	LS-6	6V AC/DC	1W (6V)		LSTD-6*
30	LS-8	12V AC/DC	1W (18V)	BA9S/13	LSTD-1*
Bulb: ø11	LS-2	18V AC/DC	1W (24V)	DA93/13	LSTD-2*
Length: 23	LS-3	24V AC/DC	1W (30V)		LSTD-2*

	Replacement LED Lamp					
	Part No.	Color Code	<b>Operating Voltage</b>	Base		
	LSTD-6*		6V AC/DC	BA9S/13		
	LSTD-1*	R, G, A, S,	12V AC/DC			
	LSTD-2*	PW	24V AC/DC	DA93/13		
	LSTD-2*		24V AC/DC			

• Specify a color code in place of \* in Part No. R (red), G (green), A (amber), S (blue), PW (pure white) • Use a PW (pure white) LED lamp for Y (yellow) illumination.

# Transformer


	Shape	Rated Voltage	Operating Voltage Range	Ordering No.	Applicable Load
6V		100/110V AC	100/110V AC ±10%	TWR516	
		200/220V AC	200/220V AC ±10%	TWR526	LSTD-6* (6V AC/DC, LED lamp)
		400/440V AC	400/440V AC ±10%	TWR546	
24V		100/110V AC	100/110V AC ±10%	TWR512	
CE		200/220V AC	200/220V AC ±10%	TWR522	LSTD-2* (24V AC/DC, LED lamp)
		400/440V AC	400/440V AC ±10%	TWR542	

• Terminal cover (TWR-VL3) is installed on transformers as standard.

• Transformer is installed to one TW series unit.

# **Specifications**

opoonioanono		
Part No.	TWR5□6	TWR5 <sup>2</sup>
Operating Voltage	100/110V AC, 200/220V AC	, 400/440V AC (50/60Hz)
Current Draw	2.4VA	
Rated Insulation Voltage	600V	
Insulation Resistance	100MΩ minimum (500V DC	megger)
Operating Temperature	-30 to +60°C (no freezing)	
Operating Humidity	35 to 85% RH (no condensa	ation)
Storage Temperature	-40 to +80°C (no freezing)	
Vibration Resistance	Damage limits: 30Hz, ampli Operating extremes: 5 to 55	
Shock Resistance	Damage limits: 1,000 m/s <sup>2</sup> Operating extremes: 100 m	/S <sup>2</sup>
Dielectric Strength	2500V AC, 1 minute	
Terminal Screw	M3.5	
Applicable Wire	2mm <sup>2</sup> maximum, 2 wires m	aximum
Weight (approx.)	87g	



	Po
	LE
	Co
T _	Op Int
╞╫╧┟╱	Int

All dimensions in mm.

# Accessories

Shape	Material	Part No.	Ordering No.	Package	Dimensions (mm)	
				Quantity		Flush Silhouette
DIN 35mm Rail						ø16
	Aluminum Length: 1000mm	BAA1000	BAA1000PN10	10		ø22
Weight: 200g approx.						ø30
DIN 35mm Rail					<u>12.5 + 12.5 1.0 + 1</u>	Miniature
	Steel	BAP1000	BAP1000PN10	10		Pilot Lights
	Length: 1000mm	DAP1000	DAPTOUOPNTU	10		
Weight: 320g approx.						
End Clip	Metal					HW
	(zinc-plated steel)					тw
2013	Applicable rail: BNL6 BAA1000	BNL6PN10	10		YW	
Weight: 15g approx.	BAP1000					

• See H-071 for DIN rail products.

# 🗥 Safety Precautions

- Turn off the power to the TW series switches & pilot lights before starting installation, removal, wiring, maintenance, and starting installation, removing, wiring, maintenance, and inspection of the products. Failure to turn power off may cause electrical shocks or fire hazard.
- To avoid a burn on your hand, use the lamp holder tool when replacing lamps.
- . For wiring, use wires of a proper size to meet the voltage and current requirements. Tighten the terminal screws to the recommended tightening torque (see B-268). Failure to tighten terminal screws may cause overheat and fire.
- When using a commercially available lamp, choose a lamp with rated voltage 5 to 30V AC/DC and 1W maximum, and with the same base and shape. Make sure of correct operation before installation. The operation of illuminated pushbutton switches cannot be guaranteed when a commercially available lamp is used.

Control Boxes Emergency

Terminal Blocks

Relays & Sockets

wer Supplies

Sensors

AUTO-ID

# Panel Mounting

Panel thickness adjustment ring is used for the TW series. To attach the TW series to the panel, follow the procedures below.

Panel Thickness Adjustment See "Adjusting Panel Thickness" below.



Panel thickness adjustment ring

Beze

l ens

Panel thickness scale

# Mounting the Unit onto the Panel

After adjusting the panel thickness, attach the unit to the panel with the panel thickness scale facing up, and attach the bezel. See "2. Installing the Round/Square Bezel" for installing the bezel.

Attach a nameplate before installing the bezel.

Attaching the Button, Lens,

line A, as shown below.

and Knob Circuit Protectors

See "3. Installing Buttons, Lenses, and Operators." Power Supplies

LED Illumination


Controllers 1. Adjusting Panel Thickness Operator The panel thickness ring provides adjustment from 1 to 6 mm in 0.1-Interfaces mm increments. Set the panel thickness to line A. Rotate the ring until Sensors the desired thickness indication around the periphery is aligned with

AUTO-ID

Flush Silhouette ø16 ø30 Miniature Pilot Lights

нw


YW



Note: When a nameplate or an anti-rotation ring is used, add 0.8 mm to the panel thickness.

Total thickness = Panel thickness + 0.8 mm (nameplate or anti-rotation ring thickness)

When the adjustment value is 1, 1.6, 2, 2.3, 3.2, or 3.5 mm. Panel thickness can be adjusted easily to the values shown below by inserting the contact block removal tool between the adjustment ring and base.



# 2. Installing the Round/Square Bezel Round bezel

All round bezels are screw-in type. Be sure to use the locking ring wrench (OR-14) to tighten the bezel to a torque of 2.0 N·m.





Use side B when mounting the units closely.

# Square bezel

Install the TW series on the panel from the back, and follow the instructions below.

(1) Insert the base plate from the front. (2) Insert the lock nut. For easy installation, use the nut locking wrench.

(3) Mount the square bezel. The bezel will snap onto the base plate.

Square Bezel





Lock nut can be installed easily by using the nut locking wrench (TW-KQ2). Tightening torque is 2.0 N·m.

# 3. Installing Buttons, Lenses, and Operators Pushbuttons

Flush/Extended/Square

Push in the button to install.



Mushroom Button has threads. Turn clockwise to install the button.



# Illuminated Pushbutton/Pilot Light Lens

Extended Lens has threads. Turn clockwise to install the button.



**Round/Flush** Lens has threads. Turn clockwise to install the button.





Nut Locking Wrench

APEM

Control Boxes

Emergency Stop Switches

Enabling

Switches

Safety Products


Explosion Proof

Terminal Blocks

Relavs & Sockets

# Installing the Operator on Selector Switches

- Install the switch with TW marking facing upward, so that the operator can be installed on the switch in the correct direction.
- (2) On non-illuminated models, install the color insert in the middle of operator. The color insert also serves to retain the operator.






(3) On illuminated models, align the operator with the switch by confirming the TOP marking on the switch and also the switch operation. Then press in the operator into the switch.




# Installation of Selector Operators

The shaft of each non-illuminated selector switch has a recess to identify the direction to install the operator. Align the operator with the recess and press in the operator. Press a color insert (non-illuminated) into the operator (illuminated selector switches do not have a recess on the shaft).

# Non-illuminated Selector Switches



In addition to the standard positions shown below, the non-illuminated operators can be installed 45° intervals.



(Standard positions)

# Illuminated Selector Switches



In addition to the standard positions shown below, the non-illuminated operators can be installed  $45^{\circ}$  intervals.

(Ex.)

2

(Standard positions)

# Removing the Buttons and Lenses Pushbuttons

# Flush/Extended/Square

Insert a flat screwdriver between the button and the bezel to remove the button



# Extended The lens has threads. Turn the lens counterclockwise to remove.

Square Lens

Insert a flat screwdriver between the lens and bezel, and tilt the screwdriver to remove the lens.

# \Lambda Notes

- The square lens of the illuminated pushbutton cannot be used without waterproof lens. Always use the waterproof lens.
- Be sure to use the marking plate even when marking is not required.

operator.

# Non-illuminated Selector Switches



Insert a flat screwdriver with tip width 4.5 mm maximum into the recess under the color insert. Turn the screwdriver to push out the insert from the operator.

Pull out the operator sideways as

shown in the left photo to remove the



Illuminated Selector Switches



Insert a flat screwdriver with tip width 5 mm maximum into the recess opposite from the color insert and tilt. The operator is displaced slightly.



LED IIIUMINAUO
Controllers
Operator Interfaces
Sensors
AUTO-ID

Flush Silhouette
ø16
ø30
Miniature
Pilot Lights

HW	
YW	

APEM

Control Boxes

Emergency

Enabling Switches

Stop Switches

Safety Products

Explosion Proof

Terminal Blocks

Relays & Sockets

Power Supplies

Circuit

Protectors



ht Lens Round/Flush The lens has threads.

Mushroom

The button

has threads.

to remove.

Turn the button

counterclockwise

APEM

Control Boxes Emergency Stop Switches Enabling

Switches

Safety Products

Explosion Proof

Terminal Blocks

Relavs & Sockets

Circuit

ø30

нw

YW

Miniature

Pilot Lights

# **Operating Instructions**

# **Removing the Contact Blocks/Full Voltage Adapters**

Insert a flat screwdriver (4 to 6 mm) into the snap-fit latches of the contact block or full voltage adapter and lift to remove.

Latches


- Make sure to lift both latches. Contact blocks cannot be removed by lifting one latch only.
- · Do not apply excessive force to the
- latches, otherwise damage maybe caused.

# **Transformer Units and DC-DC Converters**

Insert the end of the contact block removal tool (TW-KC1) into the snap-fit latch of the transformer units or DC-DC converter and pull the tool forward.

The contact block removable tool cannot be used to remove the contact blocks (HW-U), full voltage adapters (HW-GA1N), or dummy blocks (HW-DB).

# Illuminated Pushbuttons/Illuminated Selector Switches



# 🗥 Notes on Replacing Units


When replacing parts (contact block, dummy block, full voltage adapter, transformer) for maintenance, make sure to install the parts to the original position. Otherwise proper operation cannot be guaranteed.

Using a Ring Adapter


# • HW9Z-A25

Install the ring adapter between the HW series unit and panel. Make sure that the side with ridges face the panel.





Installation









# **Marking Plate**


# Round Pilot Lights (Marking Type)



 Square Pilot Lights (Marking Type)



• Square Illuminated Pushbuttons



# Marking Plate Engraving Area


Marking is possible on all square lens. To engrave, take out the marking plate inside the lens.

Round	Round (ø29/ø40)	Square (Pilot Light)	Square (IIIIuminated Pushbutton)
Ø17 H4.7	ø15.7 H2.4		

Note: The depth of the engraving must be within 0.5 mm.

# **Removing the Marking Plate**

 Pilot Lights Insert the screwdriver into the recess of the lens.



# **Removing the Marking Plate**

 Illuminated Pushbuttons Remove the lens retainer by inserting a small flat screwdriver into a recess with a projection on the lens, and tilt lightly. Turn over the lens to remove the marking plate. Lightly tap the lens on a flat surface if necessary.


# Installing the Lens Retainer

Install the marking plate into the lens, with flat surface facing the lens. Then install the lens retainer into the lens, by fitting a projection of the lens retainer into the recess with projection as shown at right.

Turn over and press as shown at right so that the lens retainer is installed securely.

# with tip width 5 mm max. Latch engaged

Flat screwdriver





# 🗥 Notes

The square lens of the illuminated pushbutton cannot be used without waterproof lens. Always use the waterproof lens. Be sure to use the marking plate even when it is not engraved.

# Installing Round Lens and Waterproof Lens



When installing or removing round lens of pilot lights and illuminated pushbuttons and waterproof lens of square pilot lights and illuminated pushbuttons, press the rubber part of the contact block removal tool onto the lens or waterproof lens for secure tightening and easy removal.

# **Replacement of LED Lamps**

Lamps can be replaced by using the lamp holder tool (OR-55) from the front of the panel. (See B-257 for lamp holder tool.)

# • How to Remove

To remove, slip the lamp holder tool onto the lamp head lightly. Then push slightly, and turn the lamp holder tool counterclockwise.

# How to Install

To install, insert the lamp head into the lamp holder tool. Place the two pins on the lamp base to the grooves in the lamp socket. Inset the lamp and turn it clockwise.



# Selector Switches


Turn the operator such as knob, lever, and key to each position accurately. Releasing halfway may cause the operator to return to the former position, or to get stuck between. On spring return two-way types, the center of operators may be misaligned slightly.

# **Key Selector Switches**

Insert the key completely before turning. Failure to do so may cause failures

# **Collective Mounting**


When mounting the units closely in a horizontal row on 30-mm centers, use optional barriers (HW-VU1) to prevent interconnection between adjoining terminals. The barriers can be attached simply by pressing them onto the sides of contact blocks.




- Use a barrier (HW-VU1) between the contact blocks.
- Sufficient insulation distance cannot be obtained if barriers are not installed. or when other barriers such as HW-VG1 is used.

# Notes on Wiring Transformer Type Units

When using transformer type illuminated TW series of 240V AC maximum closely in a horizontal row on 30 mm centers, insert straight the solid wires or stranded wires into inside of the terminal screw on the transformer (see figure below) to prevent short circuit between adjoining terminals.





When using transformer type pilot lights closel and vertical rows on 30 mm centers, keep the below 40°C.

rs ist	Pil
	-11
ן איי	ΗV
ly mounted in horizontal	
ambient temperature	Y٧

Pilot Lights
Control Boxes
Emergency Stop Switche
Enabling

APEM

Switches Safety Products

Explosion Proof

Terminal Blocks

Relavs & Sockets

Circuit Protectors

Power Supplies

LED Illumination Controllers

Operator Interfaces

Sensors AUTO-ID

Flush Silhouette ø16 ø30 iniature lot Lights


# Applicable Wiring

(1) Contact Block 0.3 to 3.5 mm<sup>2</sup> (solid wire Ø0.5 to 2.0 mm) Pushbutton/illuminated pushbutton/selector switch/ illuminated selector switch

(A) and (B) show the wiring direction to the terminals.

# <Contact Block>

Terminal screws M3.5 (spring-up)



# **Applicable Crimping Terminal**

Be sure to use an insulation tube or cover on the crimping part of the crimping terminal to prevent electrical shocks.

Crimping terminal for (A)

IP20 crimping terminal


Crimping terminal for B IP20 crimping terminal

ø3.6 to 4.3

6 min.

ø3.6 min

6 min



6 min.




# **Applicable Crimping Terminal**


110V DC, 380V

Be sure to use an insulation tube or cover on the crimping part of the crimping terminal to prevent electrical shocks.


Crimping terminal for (A)



# Crimping terminal for (B)







- · Strip the wire insulation 7 to 8 mm from the end.
- Insert the wire until the insulation comes into contact with the terminal metal part.
- Terminal cover is integrated in the full voltage adapter and transformer unit. Note that the connection terminal is not IP20.

# ø16 6.6 max

Flush Silhouette

ø30 Solid wire Miniature Pilot Lights

- max ø2.0 I
- нw

YW

# (1)-1 IP20 Degree of Protection

8 to 9mm

The terminal of HW-U contact block has IP20 degree of protection. When IP20 is required for wiring, observe the followings. Make sure to insert the crimping terminal or wire to the terminal straight and fully.

# When using a crimping terminal

Use IP20 crimping terminals.

# When using a solid wire

Strip the wire insulation 8 to 9 mm from the end and insert the wire to the terminal fully.

# When using a stranded wire

Strip the wire insulation 8 to 9 mm from the end and insert the wire to the terminal fully. Make sure that the wires are not loosened.

APEM

Control Boxes Emergency Stop Switches

Enabling

Switches

Safety Products

Explosion Proof

Terminal Blocks

LED Illumination

Controllers

Operator

Interfaces

Sensors

AUTO-ID

7 max

4 max

4 max

<Transformer Unit> 100/110V AC, 200/220V Terminal screws M3.5 (spring-up)


<DC-DC Conver Unit/Transformer Unit>

Terminal screws M3.5 (spring-up)

(2) Power Unit

<Full Voltage Adapter>


Terminal screws M3.5 (spring-up)



0.3 to 2 mm<sup>2</sup> (solid wire Ø0.5 to 1.6 mm)

Illuminated pushbutton/illuminated selector switch

(A) and (B) show the wiring direction to the terminals.





- . Strip the wire insulation 8 to 9 mm from the end
- Insert the wire until the insulation comes into contact with the terminal metal part.




(3) Pilot Light  $0.3 \text{ to } 2 \text{ mm}^2$  (solid wire  $\emptyset 0.5 \text{ to } 1.6 \text{ mm}$ )


# Applicable crimping terminal

Be sure to use an insulation tube or cover on the crimping part of the crimping terminal to prevent electrical shocks.

# <Full Voltage Type>

6V, 12V, 24V AC/DC Terminal screws M3.5 (self-lifting)







# <Transformer Unit>


100/110V AC, 200/220V AC (240V AC maximum) Terminal screws M3.5 (spring-up)

Crimping terminal for A

Crimping terminal for B










# <DC-DC Converter Unit/Transformer Unit> 110V DC, 380V AC minimum

Terminal screws M3.5 (spring-up)





# Solid wire



• Strip the wire insulation 7 to 8 mm from the end.

• Insert the wire until the insulation comes into contact with the terminal metal part.

• Install a terminal cover to 6, 12, 24V AC types. The connection terminal is not IP20.

• Terminal cover is integrated in the transformer and DC-DC converter unit. Note that the connection terminal is not IP20.

• When selecting mounting centers and crimping terminals, take sufficient insulation distance into consideration.

# **Cautions for Wiring**

# About using DC-DC Converter Unit

1. Note the polarity for wiring when connecting to the DC-DC converter.

	•	
Terminal No.	Polarity	
X1	Positive	
X2	Negative	APEM
		Cuuitab

2. Incandescent lamps cannot be used in DC-DC converter unit.

 DC-DC converters are equipped with an electric circuit and noise may be heard inside the unit, which does not affect the performance of DC-DC converters.

# **Recommended Tightening Torque Number of Wires**

Unit	Wire		Number of Wires	Recommended Tightening Torque	Terminal Screw	Safe
						Explo
HW-U Contact Block	Crimping Terminal		2	1.0 to 1.3		Term
	Solid Wire	ø0.5 to 1.6 mm (AWG14 to 22)	2	1.0 to 1.3	M3.5	Relay
		ø1.7 to 2.0 mm (AWG12)	1	1.2 to 1.3		Circu Prote
	Stranded Wire	0.3 to 2.0 mm <sup>2</sup> (AWG14 to 22)	2	1.0 to 1.3		Powe
		2.1 to 3.5 mm <sup>2</sup> (AWG12)	1	1.2 to 1.3		LED
Illuminated Unit (*1)	Crimping Terminal					Cont Oper
	Solid Wire	ø0.5 to 1.6 mm (AWG14 to 22)	2	1.0 to 1.3	M3.5	Inter Sens
	Stranded Wire	0.3 to 2.0 mm <sup>2</sup> (AWG14 to 22)				AUTO
Pilot Light	Crimping Terminal					
	Solid Wire	ø0.5 to 1.6 mm (AWG14 to 22)	2	1.0 to 1.3	M3.5	Flush
	Stranded Wire	0.3 to 2.0 mm <sup>2</sup> (AWG14 to 22)				ø16

\*1) Lamp terminal of illuminated pushbuttons and illuminated selector switches

	APEM				
-	Switches & Pilot Lights				
,	Control Boxes				
	Emergency Stop Switches				
;	Enabling Switches				
1	Safety Products				
	Explosion Proof				
	Terminal Blocks				
	Relays & Sockets				
	Circuit Protectors				
	Power Supplies				
	LED Illumination				
	Controllers				
	Operator Interfaces				
	Sensors				
	AUTO-ID				
	Flush Silhouette				
	ø16				
1	ø22				
	ø30				
	Miniature				
	Pilot Lights				
	HW				
	TW				
	YW				

Switches & Pilot Lights